FATIGUE EVALUATION OF PIPING CONNECTIONS UNDER THERMAL TRANSIENTS

C.T.E. DeAquino and J.E. Maneschy

COPESP - Coordenadoria para Projetos Especiais, Av. Professor Lineu Prestes 2242,
Cidade Universitária, São Paulo, Brasil 05508-900

1. Introduction

In designing nuclear power plant piping, thermal transients, caused by non-steady operation conditions, should be considered. These events may reduce considerably the lifetime of the pipes, creating the necessity of using structural elements designed in such a way to minimize the acting thermal stresses.

Typical examples of the usage of these elements are the connections between pipes of small and large diameters, in which it is usually used a weldolet. Nevertheless, in some situations, the thermal stresses caused by the transients are greater than the allowable limits, being, in this case, an alternative for best results, the introduction of a special fitting replacing the weldolet, as can be seen in figure 1. Such a fitting is designed in a way to permit a better distribution of the stresses, reducing its maximum value to acceptable levels.

This paper intends to present a fatigue evaluation of a connection, using the above mentioned fitting, when subjected to a load expressed in terms of a step thermal gradient, varying from 263°C to 40°C.

Two different methodologies are used in this analysis:

- (a) Determination of the temperature distribution from the heat transfer equations for piping, being the stresses calculated according to ASME III NB-3600 [1].
- (b) Thermal and stress analyses using axisymmetric elements, according to the rules presented at ASME III NB-3200.

In the first case, named simplified analysis, the computer code used is the PIPESTRESS [2], while in the second case, the ANSYS program [3] was adopted.

2. Operating conditions and material properties

The connection studied in this paper consisted of two class 1 pipes, whose nominal diameters are 3/4" and 3", both schedule 160", plus the special fitting, shown in figure 1, with a length of 195 mm and angle of 10°.

The material used in this connection was the austenitic stainless steel SA 376 TP 347, with design pressure and temperature of 16.5 MPa and 343°C, and normal operating conditions of 13.2 MPa and 263°C. The rates of mass flow are 0.266 kg/s and 1.213 kg/s through 3/4" and 3" pipes, respectively. The material properties at 151°C are:

- . Young modulus = 190 GPa
- . thermal expansion coefficient = 17×10^{-6} mm/mm°C
- . specific heat = 0,5 kJ/kg°C
- . thermal conductivity = 17×10^{-3} W/mm°C
- . density = 7600 kg/m³

The thermal transient specified for this paper considered the connection initially at a temperature of 263°C, being in a subsequent time subjected to a sudden injection of water at 40°C through the pipe of smaller diameter.

FIGURE 1 - Special fitting with a thermal sleeve

3. Thermal analysis

In the simplified analysis it has been supposed that the temperature distribution at the special fitting, of figure 1, could be calculated using a model that connected directly the pipes of 3/4" and 3" diameters. According to subsection NB-3650 [1], the temperature distribution at the wall of the piping, calculated through a unidimensional heat transfer model, is divided into three parts: uniform, linear and non-linear. Each of these parts was determined by the PIPESTRESS program from the transient regime heat transfer equations, supposing axial symmetry. In order to get good accuracy, since the method of solution of the equations is finite differences, the thickness was divided into many elements.

The film coefficient, responsible for the heat rate flowing through the pipe wall, was automatically calculated, since the PIPESTRESS program has internal tables that allow the determination of the fluid properties (viscosity,

conductivity, specific volume, Reynolds and Prandtl numbers) from the values of pressure and temperature at each time.

The thermal analysis was performed after the definition of geometry and material properties, plus service level conditions and the thermal transient acting on the pipe.

In the detailed analysis, the special fitting (figure 1) was represented by thermal isoparametric solid elements, with axisymmetry option, identified as STIFF55 in the element library of the ANSYS program [3]. The finite element mesh was automatically generated from the definition of keypoints and line segments, used to limit the areas to be divided into elements, as can be seen in figures 2A and 2B.

The hypothesis of axisymmetry was based on the work by Cesari [4], in which the author showed that, provided that the larger diameter pipe was modelled as a sphere whose radius is 3 times the original radius of the piping, this was a conservative approach.

The boundary conditions for this case took into account different values of film coefficient, that had to be furnished to the ANSYS program, obtained from expressions defined in [5]. The boundary conditions were applied to inside walls, being all other surfaces considered adiabatic.

In this analysis, it has been supposed a initial uniform temperature field of 263°C , applied at all nodes of the model. At a time immediately after the initial, the nodes were subjected to a thermal transient, due to the injection of water at 40°C through the $3/4"$ piping, during 3 minutes. It was assumed, for the scope of this analysis, that after 4 minutes the system reached a thermal steady-state regime.

FIGURE 2 - Finite elements model (a) general view
(b) detail

4. Stress analysis

The computation of the stresses obtained in the fatigue analysis considered only the effects due to the thermal transient, being, therefore, the effects due to pressure and bending moments (due to mechanical and thermal loads) not taken into account.

In the simplified model, where the rules of ASME Code section III NB-3600 were obeyed, the determination of the peak stress, S_p (eq.11 of NB-3650), was made from the superposition of the stress contributions of the uniform, linear and non-linear temperatures, all previously obtained. The stress indices adopted were those related to weldolet.

For the stress analysis of the detailed model, it has been used the bidimensional isoparametric solid element, with axisymmetry option, identified as STIF42 at the ANSYS'element library [3].

The boundary conditions for this case took into account the continuity of the larger diameter piping. Because of that, those nodes of the model positioned the most to the right had their thermal displacements restrained in such a way to simulate the situation when a continuity of the pipe exists.

The loads considered for the determination of stresses were nodal temperatures at the time when the thermal gradient along the thickness of the pipe is maximum.

5. Results

In the case of the simplified model, the analysis performed with PIPESTRESS determined the stress contributions due to uniform, linear and non-linear temperatures, at each time and indicated the maximum value to be used in each of the NB-3650 equations [1]. In this case, only the peak stress was calculated, having been obtained the value of 930 MPa. Using fatigue curves from ASME III Appendices [1], for the material of the connections, the number of cycles N , correspondent to the lifetime of such a part and obtained from the input of

$$S_{alt} = 3,33 \times S_p / 2,$$

equaled 100 cycles.

For the detailed analysis, the time for a maximum temperature gradient across the thickness was defined and, from that, the peak stress was obtained only at this time. ANSYS program [3] provided the stress at each node of the section shown in figure 3, as well as at all other nodes, being the critical value (567 MPa) located at node 854. In this case, following the same procedure used for the simplified analysis, the number of cycles N obtained was 700 cycles.

FIGURE 3 - Section used in stress calculations

6. Conclusion

The existence of thermal transients at piping connections produced high stress levels, resulting in a reduction of the lifetime of such structural parts.

An alternative to minimize this problem is to use a special fitting with thermal sleeves, as shown in figure 1, that allows a better temperature distribution that will cause a reduction of the acting stresses.

However, the application of such a fitting would be only advantageous if the whole analysis is performed following the rules of ASME NB-3200 [1].

In spite of increasing the cost, complexity and time consumption, the results obtained this way show a more realistic estimation of the lifetime of the connection.

7. References

- [1] ASME Boiling and Pressure Vessel Code, Section III, 1989
- [2] PIPESTRESS, version 3.4.02, 1991
- [3] ANSYS, version 4.4A, 1989
- [4] Cesare F., Equivalent nozzles in thermomechanical problems, Intl'. Journal of Pressure Vessels and Piping, 1979
- [5] Heat Transfer, Holman, McGraw-Hill, 1982 (in Portuguese)