



## **Historical Development of the Seismic Requirements for Construction of Nuclear Power Plants in the U.S. and Worldwide and their Current Impact on Cost and Safety**

John D. Stevenson<sup>(1)</sup>

**KEY WORDS:** Seismic Requirements, Construction, Nuclear Power Plants, U.S., Worldwide, Current Impact, Cost, Safety

### INTRODUCTION

Seismic design requirements applicable in Nuclear Power Plants in what has been defined in the West, over and above what might be required by individual National Building Codes for conventional industrial Structures, Systems and Components, began in the early to mid 1960's. For example, there were 5 nuclear power plants designed in that era in the U.S. which had no seismic design requirements. This approach continued in Finland, Sweden and Great Britain and East block countries until the mid 1980's. During this period for most sites except in recognized active earthquake regions, the resultant seismic lateral loads required for use in design were typically less than applicable lateral wind loads and would result in little or no damage to engineered industrial facilities. As a result they had little or no impact on design or construction.

In the U.S. the National Building Code (UBC-67) lateral peak ground accelerations ranged from 0.025g to 0.1g as shown in Figure 1.<sup>(1)</sup> While such loads were not defined on a probabilistic basis these peak ground acceleration values would appear to range from about  $2 \times 10^{-2}$  to  $1 \times 10^{-2}$  per year probability of exceedence or return periods of 50 to 100 years which was consistent with wind return period design requirements.

These design basis ground accelerations correlated with Modified Mercalli or Medvedev, Sponheuer, Karnik, MSK-64 damage and behavior intensity scale levels of V to VII. Earthquake experience studies indicate that significant damage or malfunction of industrial type facilities, even when they are not explicitly designed to resist earthquakes, do not occur until the upper region of Intensity Level VI or the lower region of Intensity Level VII is reached at or about 0.08 to 0.10g pga<sup>(2)</sup>. For this reason minimum pga have been established for nuclear power plant design purposes by the International Atomic Energy Agency at 0.1g pga in 1979 with publication of their Safety Guide S-1.<sup>(3)</sup> Specified acceleration values below 0.1g pga or spectral values less than 0.2g simply do not cause damage to engineered structures, systems and components even when they are not designed to be earthquake resistant. However, they are capable of causing damage to architectural components such as un-reinforced masonry, plaster, glass and ceramics

It should be understood that the mid to late 1960's seismic design requirements are not as unconservative as they may appear by comparison to today's requirements expressed in terms of peak ground acceleration. Seismic designs during this period were based on elastic analysis. Later National Building Codes (1988 in the U.S.)<sup>(4)</sup> increased seismic pga significantly by defining a seismic zone coefficient

---

<sup>(1)</sup> Senior Consultant, J.D. Stevenson Consulting Engineer, 9217 Midwest Avenue, Cleveland, Ohio 44125, Phone: 216-587-3808, Fax: 216-587-2205, E:mail: jstevenson4@earthlink.net

equivalent to pga which range between 0.075 to 0.4g. However, they also permitted implicit inelastic behavior by the introduction of a factor (R) for building structures which ranged between 4 and 12 and  $R_p$  which ranged from 2 to 6 for non-building and mechanical and electrical equipment and distribution systems as a function of the type of structure and materials of construction. The R or  $R_p$  factors were used as a divisor to reduce the elastically computed seismic moments and forces which in turn are used to compute resultant stresses to be compared to Code defined or referenced acceptance criteria.

## HISTORICAL DEVELOPMENT OF NPP SEISMIC DESIGN REQUIREMENTS

### PEAK GROUND ACCELERATION

In Table 1 is a commonly used comparison of the relationship between peak ground acceleration and Modified Mercalli or MSK-64 intensity scale levels. These Intensity scales, as well as the Japanese Meteorological Agency (JMA) scale, are summarized in Attachment A hereto. Most of the Eastern European Nuclear Power Plants original design were specified as MSK-V or at approximately 0.025g pga hence, effectively had no impact on design.

In the U.S. the first departure from the National Building Code requirements was to identify a second Maximum Hypothetical Earthquake, MHE level starting in 1966 which was typically defined as the largest earthquake in recorded history that had occurred within 300 km (200 miles) of the site with its epicenter intensity region moved to the site. This MHE often typically had a pga 4 to 8 times that of the National Building Code defined earthquake from the 1967 UBC and began the practice of defining earthquake peak ground acceleration on a site specific basis.

An example of this application was the Connecticut Yankee NPP which was originally designed for a 0.03g pga using the requirements of UBC-64. Detailed design of this plant started in early 1964 and was completed in mid 1967. In 1966 the plant was re-evaluated for a 0.17g pga well after the plant design and construction were well underway.

The MHE nomenclature was soon dropped in favor of a Design Basis Earthquake nomenclature and by the early 1970's had been redefined in the U.S. as the Safe Shutdown Earthquake, SSE. In addition, a smaller (usually taken as one half the SSE in the U.S.) earthquake was defined as the Operating Basis Earthquake, OBE which had more conservative behavior criteria and damping values specified. As a result in many instances it was determined that the smaller Operating Basis Earthquake controlled design.

Other countries such as Canada and Japan did not follow the U.S. example but instead defined a different design level earthquake applicable to different sets of structures, systems and components which had a different impact on safety. The Canadians defined two earthquakes, the Site Design Earthquake, SDE and a larger Design Basis Earthquake, DBE.<sup>(5)</sup> The Canadian DBE is evaluated on a case-by-case basis as described in Reference 5. The SDE on the other hand is defined on a probabilistic basis as having a return period of 100 years or a probability of exceedence of 0.01.<sup>(6)</sup>

The Japanese developed 4 earthquake levels  $A_s$ , A, B and C for design purposes as shown in Tables 2 and 3.<sup>(7)</sup> In general the  $S_1$  earthquake lower bound limit for Japan has been taken as 0.27g corresponding to a Surface Magnitude 6.5 peak ground acceleration and  $S_2$  typically 1.5 times higher or 0.4g at the rock foundation media interface at the site. Initially all Japanese NPP were founded on rock. Higher level peak ground acceleration on a site specific basis are specified for regions of Japan with higher seismic potential.

Most other countries, except Sweden, Finland and Great Britain, which did not consider earthquakes applicable to their sites as well as the East Block countries until the 1980's, tended to follow the two

earthquakes OBE and SSE U.S. procedures which were also identified in the IAEA Safety Guide S-1 as the S<sub>1</sub> and S<sub>2</sub> earthquakes in 1979.<sup>(3)</sup> It should be noted that most existing NPP, regardless of their original seismic design basis, have or are planning to re-evaluate their ability to resist earthquakes.

## RESPONSE SPECTRA AND DAMPING

From the beginning of nuclear power plant design, attempts were made to perform some type of dynamic analysis. Initially this was performed by use of ground response spectra. In the U.S. ground response spectra first developed by Dr. G. Housner in 1953<sup>(8)</sup> were applied to nuclear power plant facilities by TID 7024 Nuclear Reactors and Earthquakes<sup>(9)</sup> using the Housner free field ground surface response spectra as shown in Figure 2.

In the period 1964 to 1967 dynamic analysis was usually accomplished by applying the peak of the Housner defined ground response spectra to structures, equipment or distribution systems as function of their specified damping value as shown in Table 4. For example, in seismic design of piping 0.5 with the Housner Spectrum percent damping was used which had a spectral peak amplification factor of 4.2 times the pga. This acceleration was applied to the mass distribution of the piping to get resultant inertia forces on the piping which in turn were statically applied to a structural model of the piping system to get resultant stresses. For structures or equipment a similar approach was taken except that different percent damping factors typically were used as shown in Table 5. For equipment or distribution systems supported above the ground floor the pga of the ground response spectra were also increased as a function of building floor acceleration as a function of height.

It should be noted that until about 1967, when computer programs that could perform multi-degree of freedom dynamic analysis calculations became generally available multi-degree of freedom frequency calculations had to be performed by tedious hand calculation. For example, to determine the dynamic characteristics of a 5-degree of freedom system such a calculation using a mechanical calculator would typically require 150 manhours.

From 1967 to 1972 in the U.S. there was a gradual transition away from the Housner shaped spectra which was a weighted average spectra developed from averaging four recorded strong motion earthquakes 3 of which were from California to what became known as the Regulatory Guide 1.60<sup>(10)</sup> mean plus one standard deviation response spectra developed by Newmark, Blume and Kapoor recorded from 14 different strong motion earthquakes predominately from California.<sup>(11)</sup> In addition, distinct vertical spectra different from the horizontal spectra were developed as well as individual spectra applicable to rock versus soil sites.

The R.G. 1.60 free field ground surface shaped response spectra is shown in Figure 3. It should be noted these spectra, for the same level of damping, resulted in much larger amplification than was the case with the Housner Spectra. However, damping values to be used with the R.G. 1.60 were also modified as shown in Tables 4 and 5 such that the resultant seismic inertia loads coming from the R.G. 1.60 ground acceleration were approximately the same as determined by use of the Housner spectra.

More recently starting about 1992 the median shaped NUREG/CR-0098<sup>(12)</sup> ground spectra which was developed in 1978 as shown in Figure 4 has come in to use in evaluating existing NPP which has significantly less amplification than the R.G. 1.60 spectra as shown in Table 4 for the same damping value. Associated with the use of earthquake experience data in the same time frame was the Reference GIP spectrum as shown in Figure 5.

Currently a new series of generic rock Uniform Hazard Ground Response Spectra on hard rock ( $v_s=6000$ ft/sec) at Central and Eastern U.S. sites compared to soft rock ( $v_s=3000$  ft/sec) West U.S. sites as

shown in Figure 6 were developed. It is thought these hard rock shape ground response spectra are more applicable to basement hard rock motion at sites in the Central and Eastern U.S. and Western Europe and time-history motions representative of these rock motions can be used with SSI models to generate ground surface and in-structure design basis response spectra.

#### FLOOR OR AMPLIFIED RESPONSE SPECTRA

It was well known prior to the late 1960's that the earthquake ground motion was modified as this motion was transmitted from the ground through a building structure and that such motions became much more sinusoidal in nature as the building tended to respond in its dominate natural modes of vibration. Since response to sinusoidal motion is a function of 1.0 divided by 2 times critical damping, the more or less random earthquake ground motion which for 5 percent critical damping had ground amplifications of 2 to 3 had amplifications of close to 10 when filtered by the building at the dominate response natural frequency of the building. In addition, based on earthquake experience zero period acceleration at each floor elevation tended to increase as a function of the height of the building. For concrete shear wall type structures the floor zero period acceleration,  $z_p$  tends to increase by a factor of 3 from the base to the roof of the structure. For flexible moment resisting steel frames the ratio of roof to base  $z_p$  typically approaches a factor of 5.

Prior to 1967 when the heavy construction industry was limited to dynamic analysis by hand calculation there was no practical way to generate floor or amplified response spectra at the mass points reflecting the various building elevations. After 1967 with the advent of computerized dynamic analysis programs, it was possible to generate such floor or amplified response spectra. As a result peaks of design basis response spectra accelerations went from less than 1.0g with ground response spectra to typically 5 to 10 g's or higher acceleration levels at building resonance frequencies at elevated floor levels.

Typical or generic floor response spectra generated to be compatible with R.G. 1.60 ground motion spectra are shown in Figures 6 and 7. This generation of highly amplified in-structure response spectra also resulted in a virtual explosion in dynamic analysis effort for safety related distribution systems. Previously most safety related distribution systems were seismically designed by simplified support spacing tables and charts based on peaks of ground response spectra. These peak ground spectral values seldom exceeded 1.0g. With the advent of floor spectra the design of these systems was now faced with spectra having peak values of 5 – 10 g's or more. This meant that the conservative use of the peak of the applicable response spectra could no longer be used practically to design distribution systems since use of 5 – 10 g's or more inertia accelerations resulted in support spacing which were impractical and difficult to demonstrate design adequacy for evaluated temperature piping. In the case of high temperature lines use of peak floor spectra resulted in excessive restraint of free-end displacement stresses which violated code acceptance criteria. This resulted in the excessive use of dynamic restraint snubbers which were unreliable, costly and require constant operational testing and maintenance.

The use of floor or amplified response spectra has also pushed NPP owners to spend the time and effort to develop site specific time histories or ground response spectra. Because they are site specific related, such time histories or spectra tend to be less conservative than generic spectra such as R.G. 1.60, NUREG/CR-0098 or GIP Reference spectra.

The generation of a site specific spectra generally involves the selection of a suite of typical recorded time history strong motion earthquake motions as a function of 1) type of faulting, normal, reverse or slip; 2) postulated earthquake magnitude; 3) stress drop; 4) attenuation relationships with distance between the focus or epicenter and the site. The motions thus selected are deconvoluted at the recorded earthquake site to underlying rock (i.e., shear wave velocity greater than 3000 feet per second) in order to obtain typical base rock motion. An aggregate of this rock time history rock motion would then be applied to an

SSI model of the NPP site to get the resultant ground motion time history or response spectra to be applied to or in the NPP structure.

### EFFECTIVE HIGH FREQUENCY RESPONSE SPECTRA

The development of high frequency earthquake response spectra as shown in Figure 5<sup>(15)</sup> applicable to sites underlain by hard rock has required a new focus on the damage effects of high frequency (>10 – 15 Hz) vibrations. Heretofore earthquake ground spectra had peak accelerations typically less than 1.0g in the 2 – 8 Hz range and associated spectral displacements in the 9 (230 mm) to 0.5 inch (12.5 mm) range. Above 10 Hz spectral displacements drop rapidly as a function of spectral accelerations divided by frequency squared. At 15 Hz a 1.0g acceleration divided by frequency squared would typically result in less than a 0.16 (4 mm) inch displacement.

It is a well established fact that high frequency vibrations as a function of acceleration levels cause less damage than the same acceleration at lower frequencies. This is illustrated by Figure 8 which shows a threshold of cracking for un-reinforced masonry response spectra.<sup>(15)</sup> At 5 Hz the cracking threshold is 1.0g while at 10 Hz it is approximately 2.0g and at 20Hz it is 3.0g and drops to 0.1g at 2.5 Hz. While it has been a usual procedure to use acceleration based response spectra for design purposes for frequencies below 10 Hz, it would appear to be much more rational to use displacement spectra for design purposes above 10 Hz.

A simplified analytical procedure can be found in German RSK guidelines where a constant design acceleration of 0.5g is specified for frequencies below 16 Hz associated with the vibratory input to the base of containment internal structure in response to high frequency aircraft impact on the containment shell.

The German Regulatory Authorities<sup>(16)</sup> associated with the vibratory response of containment internal structure as a result of an aircraft impact on the containment shell have also established a limit of 1.0mm displacement for frequencies above 16 Hz as a design consideration. That is to say if the spectral displacement at frequencies above 16 Hz is less than 1.0mm there is no requirement to consider the spectral values (accelerations) in design for structural evaluation of structures, equipment or distribution systems. However, such high frequency vibrations should still require consideration for seismic qualification for operability of potentially high frequency sensitive devices such as relays.

### SEISMIC MODELING PROCEDURES

Prior to 1967 and the ability to dynamically analyze multi-degree of freedom systems by computer, static models were used where the acceleration of the peak of the applicable response spectrum was statically applied to the mass distribution of the structural systems. It should be noted that such application of inertia load did not consider the effect of the shape of individual modes nor that the mode shapes could have a plus or minus sensing. As a result these statistically determined moment and shear resultants are not the same as would occur in a dynamic multi-mode analysis.

In addition, starting about 1972 the U.S. Regulatory Authorities required the application of a coefficient of 1.5 times the peak response spectra to compensate for the equivalent static and multi-frequency nature of the load application. At any given point in a structural system the seismic inertia induced stresses determined statically are different from those induced by dynamic loading. However, the equivalent static analysis procedure has generally been accepted as a reasonable approximation of dynamic analysis results.

Starting in 1967 the first dynamic models of structural systems single or multiple lumped mass models where the stiffness of the restraining elements was represented by springs. Generally only two translational degrees of freedom one vertical and one horizontal were considered. This model type was followed by replacing the spring supports by with a 6x6 stiffness matrix. Soon after this lumped mass fixed base structural models came in to use followed by foundation or support masses restrained by springs. These lumped mass models are shown in Figure 9. With the advent of three directional input it became necessary (starting around 1985) to distinguish between the center of shear and center of mass in structural modeling as shown in Figure 10.

Starting around 1971 2D finite element models particularly for slab and shell type structures appeared as well as the development of 3 translational directions of seismic input. However, because of program limitations the use of finite elements in dynamic analysis was quite limited and lumped mass models continued to be the dominant modeling format.

By 1995 the capability of computer programs had grown to the point where it was possible to represent individual structural members in dynamic finite element programs and this is currently in vogue today. Unfortunately with the advent of such complex models the analyst has generally lost the ability to visualize dominate mode shapes and associated frequencies. As a result independent simplified load path evaluations are usually necessary to assure the adequacy of the complex finite element models.

### IMPACT ON COST

In Figure 11 is shown the percentage cost of NPP seismic construction as a function of increased acceleration levels as compared to total nuclear power plant costs in the U.S.<sup>(17)</sup> using NRC approved analyses and shake table testing procedures. As can be seen by this figure seismic construction based primarily on analysis for structural integrity and testing operability adds significant cost to nuclear power plants.

The effect of seismic design acceleration levels on nuclear plant costs when costs are based primary on design by analysis and operability test qualification has long been an area of cost benefit concern to nuclear power industry owners.

In Table 6 is a summary of direct seismic and total nuclear power plant engineering and construction costs modified to represent year 2000 U.S. dollars.<sup>(17)</sup> In Table 7 is a summary of seismic total nuclear power plant costs using indirect experience data for seismic operability qualification of safety related systems and components.

Tables 6 and 7 summarize the costs in the following categories:

- (1) Site preparation and foundation media costs.
- (2) Cost of seismic site studies and response spectra generation.
- (3) Cost of building structures.
  - a. Safety related
  - b. Non-safety related
- (4) Cost of Safety Class (Seismic Category I), mechanical components--vessels, tank heat exchangers, pumps, valves, fans, dampers, etc.
- (5) Cost of Safety Class (Seismic Category IE) electrical components--generators, motor control centers, cabinets, switchgear, motors, batteries bolting racks, etc.
- (6) Cost of Safety Class (Seismic Category I) mechanical and electrical distribution and control systems--piping, tubing, ventilation duct, electrical conduit and raceways.
- (7) Engineering and other regulatory construction management costs.

Cost increments tend to be highly nonlinear for categories (1) through (5) with little or no change in cost until a particular design limit is reached, resulting in a discontinuous jump which then remains constant until a new limit is reached and another jump is encountered. For the distribution systems of category (6) costs tend to vary continuously as the square root of seismic acceleration level. In addition, the methods of engineering analysis used in evaluating components to determine seismic design adequacy as defined in category (7), tend to become more rigorous as a function of increased acceleration level with a corresponding increase in the number of distribution systems supports and unit design costs. Also, it should be understood that although engineering costs typically range between 5 and 10% of the cost of a typical component or structure, seismic analysis costs, particularly for relatively small mass produced items, can in some instances equal or greatly exceed the total cost if the item supplied is no longer standard.

### Site Preparation and Foundations

In this category the following affect costs:

- (1) Potential for liquefaction.
- (2) Potential for sliding and overturning of structures.
- (3) Potential foundation-bearing-load failure under seismic loads.

On soil sites the first and third effects are generally controlled by the use of selected engineered backfill.

The effect of overturning and sliding, assuming that a foundation failure has been precluded, depends on the energy input from the earthquake exceeding the energy required to lift and rotate or slide the structure. Common practice in analysis is to treat earthquake lateral inertia forces in each mode of response in nuclear plant design determined by accelerations. If this approach were taken on typical high-rise conventional structures, overturning would invariably result. Since overturning of such structures except as a result of liquification is not typically observed in actual earthquakes, the acceleration based equivalent static load method can lead to erroneous and overly conservative results.

Design against overturning and sliding for SSE ZPGA in excess of about 0.3g pga is usually provided by use of mat keys and increasing the lateral dimension of the building complex, that is, oversized base mats for containment or a common foundation mat with other structures. In a few instances where good, competent rock has been available, rock anchors to base mats have also been used to increase lateral stability and provide a positive hold-down connection to the foundation media. Time-history analysis or analyses which include the effect of ground motion displacement can significantly increase the apparent resistance to rigid body lateral seismic loads.

### Site Seismic Response and Generation of Site Dependent Spectra

Historically design basis response spectra used in design were defined on a generic basis such as R.G. 1.60 or IAEA Safety Guide S-1 shaped ground spectra. More recently it has become common practice to develop site specific spectra which consider the unique characteristics of the plant foundation media.

### Foundation

NPP founded on soil with shear wave velocities less than 1200 ft/sec (400 m/sec) typically require the addition of selected engineering backfill to reduce potential foundation failure to acceptable margins of safety particularly with respect to liquification or slope stability. Cost of this effort in the year 2000 dollars estimated at is 8 million.

## Building Structure

In nuclear plant building structures, the effect of increased seismic acceleration loads is usually minimal. In deformed bar reinforced concrete structures which make up most structures designed for SSE ZPGA in excess of 0.1g pga, the amount of seismic reinforcement is essentially proportional to the g-level of the earthquake.

### Seismic Category 1 Structures

- (a) Reactor containment
- (b) Reactor building internal structure.
- (c) Mechanical auxiliary building.
- (d) Electrical and control room building.
- (e) Spent fuel and high level waste storage building.
- (f) Diesel generator building.
- (g) Intake structure
- (h) Turbine building. (This structure is not normally classified as Seismic Category I, but seismic design adequacy for SSE loading is usually required to assure no gross structural collapse which could impair adjacent Seismic Category I components or structures.)

Total cost of seismic upgrading of Seismic Category I structures, which consist primarily of increased concrete wall reinforcement and ductile detailing in 2000 dollars is \$4,200,000.

### Mechanical Components

The following type components are seismically evaluated by analysis:

- (b) vertical tank – low pressure.
  - o Column supported.
  - o Skirt supported.
- (c) Vertical tank – high pressure.
- (d) Vertical heat exchangers.
- (e) Horizontal heat exchangers
- (f) Motor pump unit, vertical.
- (g) Motor pump unit, horizontal.
- (h) Fan cooler unit.
- (i) Power-operated valve.
  - o Electric.
  - o Pneumatic.
  - o Large diameter,  $\bar{>}$  10 inches, 250mm
  - o Small diameter,  $\bar{<}$  4 inches, 10mm

The total increase in NPP cost for a 0.2 to 0.3g pga seismic qualification for mechanical components is about \$14.0 million for mechanical equipment. Of this total is approximately \$0.4 million for seismic support and anchorage.

### Electrical Components

The seismic design adequacy of safety class electrical components is generally done by proof testing performed by the manufacturer on individual components. Since malfunction of component assemblies

under seismic loads is not usually amenable to analysis, the effect of increases in electrical component costs as a function of acceleration level is evaluated by change in support and cabinet and rack design requirements. The particular components considered are as follows:

- (1) Diesel generator and engineers.
- (2) Transformers.
- (3) Motor control centers.
- (4) Control panel.
- (5) Switchgear.
- (6) Instrument Panels and Racks.
- (7) Batteries and Battery Racks.

The upgrading of electrical component for a .0.2 to 0.3g pga earthquake amounts to approximately \$10.2 million with \$0.5 million of this total due to seismic anchorage requirements.

Typically, mechanical and electrical component manufacturers have tended to select their design acceleration levels for generic operability qualification of off-the-shelf components as a percentage of the potential nuclear plant market in the 85 to 95% range. These percentages in the upper limits typically fall in the 0.30g to 0.40 g SSE ZPGA range. They then qualify their components either by test or analysis for this equivalent g acceleration level response in the building structure. They are then able to supply approximately 85 to 95% of all nuclear plant jobs without any additional cost in seismic qualifying their equipment. It should be understood the cost of these seismic equipment qualification costs are passed on as increased hardware costs. The high seismic small percentages outside this range are evaluated on a case-by-case basis as a custom application potentially involving additional costs in seismically re-qualifying the equipment. The total seismic cost of design and operability qualification of mechanical and electrical components for a 0.2 to 0.3g pga design basis earthquake is \$24.2 million dollars.

#### Distribution Systems

Unlike mechanical and electrical equipment, the distribution systems tend to be custom designed for each application. In addition, the number of seismic supports required tends to increase directly with the square root of the acceleration level. Approximately 75 percent of the total cost of seismic engineering and construction is associated with distribution systems.

#### Total and Seismic Engineering Effort

Current total direct engineering man hour effort on the part of the A/E in the design and analysis of a single 1100 MWe light water commercial nuclear power plant facility is estimated at approximately 7,000,000 man hours over a ten year period. Of this total direct engineering effort, it is estimated that approximately 15% of the A/E effort (800,000 man hours) can be attributed to the seismic design requirement at the 0.2 to 0.3g pga level. This seismic design effort is shared among the various engineering disciplines associated with site evaluation; civil-structural, mechanical component; mechanical distribution systems; electrical component; mechanical distribution systems; as well as heating and ventilating duct and electrical safety related power, instrumentation and control distribution systems. It should also be understood that typically one-third of this effort in the U.S. is devoted to resolving non-conformance reports and design change notices encountered during construction essentially after design has been completed.

Approximately 75 percent of this cost results from seismic construction of distribution system (piping, conduit, cable trays, ductwork and tubing). Another 7 percent is associated with the definition of seismic input and building design with a final 18 percent in mechanical and electrical equipment anchorage and equipment operability qualifications.

## POTENTIAL USE OF INDIRECT EARTHQUAKE EXPERIENCE DATA IN DESIGN AND CONSTRUCTION OF NPP

Historically, seismic design and qualification of nuclear power plants has been based on analysis of structures, mechanical and electrical distribution systems and mechanical equipment and shake table testing of electrical equipment.

Seismic re-evaluation of existing NPP was begun by the U.S. NRC in 1978 by its Systematic Evaluation Program.<sup>(19)</sup> Results of this study suggested that NPP in the U.S. designed before 1972 should be re-evaluated for seismic design adequacy. In the U.S. approximately 69 plants fell into this category.

It was soon realized that use of conventional seismic analysis and shake table test design procedures would result in a 10 to 20 million dollar engineering effort for each NPP. As a result a Seismic Qualification Utility Group, SQUG, was organized by NPP owners which funded research into the behavior of industrial equipment and distribution systems in actual strong motion damaging earthquakes. Twenty classes of equipment were evaluated. The evaluation developed caveats as to equipment performance, anchorage requirements and spatial interaction effects with other equipment and structures all as a function of the level of seismic excitation. The SQUG evaluations and other evaluations<sup>(20)</sup> of industrial facilities response to strong motion earthquakes indicated that with careful control of the evaluation process, walkdowns of NPP could be performed and could be used to verify seismic design adequacy at a small fraction of the cost of conventional seismic analysis and tests. The applications of the earthquake experience to existing NPP typically took less than 10,000 engineering manhours per plant at a total cost including any necessary upgrade of less than \$2,000,000 dollars. As shown in Table 7, the use of the indirect method of seismic evaluation of operability of nuclear power plant equipment and standardization of the analysis of structural integrity could reduce engineering and construction costs of a NPP by \$100 million dollars or by approximately 5 percent.

Given the success of this seismic verification effort by use of earthquake experience, the obvious question is; can this procedure be applied to seismic qualification of new NPP construction?

### SEISMIC CONTRIBUTION TO SAFETY

A question which has often been asked by the nuclear power plant owners is whether or not aseismic construction is a cost effective contribution to nuclear power plant safety. Until recently it has not been possible to evaluate numerically or comparatively the contribution of seismic design to NPP safety. However, there currently are a number of well defined and documented external as well as internal Probability Safety Assessments for existing NPP. It should be possible for example, to compare the internal event core melt frequency for plants which have a 3 train safety system to a 2 train system and compare these results with the external seismic event contribution to core melt frequency.

It remains to be seen if National Regulatory Authorities would permit or support the use of PSA evaluations to quantify and compare the contribution to core melt frequency or early radiological release if the resources used in seismic analysis and testing, versus use of experienced data and walkdowns, were used to increase the number or of safety systems.

## REFERENCES

- (1) UBC-1967, "Uniform Building Code," International Conference of Building Officials, 1967.
- (2) Gumensky, D.B., "Earthquake and Earthquake Resistant Design," in Abbetts American Civil Engineering Practice Vol. III, John Wiley and Sons, Inc., 1957.
- (3) IAEA Safety Guide 50-SG-S1, "Earthquakes and Associated Topes in Relation to Nuclear Power Plant Siting," International Atomic Energy Agency, 1979.
- (4) UBC-1988, "Uniform Building Code," International Conference of Building Officials, 1988.
- (5) CAN3-N289.1, "General Requirements for Seismic Qualification of CANDU Nuclear Power Plants," National Standard of Canada, 1980.
- (6) CAN3-289.2, "Ground Motion Determination for Seismic Qualification of CANDU Nuclear Power Plants," National Standard of Canada, 1980.
- (7) JEAG 4601-1987, "Technical Guidelines for Aseismic Design of Nuclear Power Plants," Translated from Japanese, NUREG/CR 6241, June 1994.
- (8) Housner, G.W., et.al., "Spectrum Analysis of Strong Motion Earthquakes," Bull-Seismological Society, Am. 43, 1953.
- (9) TID-7024, "Nuclear Reactors and Earthquakes," U.S. Atomic Energy Commission, August 1963.
- (10) R.G. 1.60, "Design Response Spectra for Seismic Design of Nuclear Power Plants," Rev. 1, U.S. Atomic Energy Commission Regulatory Guide, December 1973.
- (11) Newmark, Blume and Kapoor, K., "Design Response Spectra for Nuclear Power Plants," ASCE Structural Engineering Meeting, San Francisco, April 1973.
- (12) Newmark, N.M. and Hall, W.J., "Development of Criteria for Seismic Review of Selected Nuclear Power Plants," NUREG/CR-0098 U.S. Nuclear Regulatory Commission, May 1978.
- (13) NUREG/CR1047, "Procedural and Submittal Guidance for the Individual Plant Evaluation of External Events (IPEEE) for Severe Accident"
- (14) ASCE 4-98, "Seismic Analysis of Safety-Related Nuclear Structures and Commentary," American Society of Civil Engineers, 2000.
- (15) Dowding, C.H., Blast Vibration Monitoring and Control, Prentice Hall International Series, 1985.
- (16) RSK Guideline Section 19.1, "Airplane Crash," 1978.
- (17) NUREG/CR-1508, "Evaluation of the Cost Effects on Nuclear Power Plant Construction Resulting from the Increase in Seismic Design Level," U.S. Nuclear Regulatory Commission, April 1981.

- (18) WRC 426, Adams, T., and Stevenson, J.D., "Differential Design and Construction Cost of Nuclear Power Plant Piping Systems as a Function of Seismic Intensity and Time Period of Construction," Welding Research Council Bulletin, November 1997.
- (19) NUREG/CR-0891, "Seismic Review of Dresden Nuclear Power Station Unit 2 for the Systematic Evaluation Program," U.S. Nuclear Regulatory Commission, April 1980.
- (20) NUREG/CR-6239, "Survey of Strong Motion Earthquake Effects on Thermal Power Plants in California with Emphasis on Piping Systems," Vols. 1 and 2 U.S. Nuclear Regulatory Commission, November 1995.

## APPENDIX A

### SEISMIC INTENSITY SCALES

#### 1. SEISMIC INTENSITY SCALE OF JAPAN METEOROLOGICAL AGENCY (JMA)

The intensity of the shock is estimated according to the scales 0 – VII, as follows:

0. *Not felt.* Shocks not felt by human beings and registered only by a seismograph, but special symbol (X) is used when shocks are felt by some neighbors, but not by observer.
- I. *Slight.* Extremely feeble shocks only felt by persons at rest or by those who are sensitive to an earthquake.
- II. *Weak.* Shocks felt by most persons, slight shaking of doors and Japanese latticed sliding doors (shoji).
- III. *Rather strong.* Slight shaking of houses and buildings; rattling of doors and Japanese latticed sliding doors (Shoji); swinging of hanging objects like electric lamps; moving of liquids in vessels.
- IV. *Strong.* Strong shaking of houses and buildings, overturning of unstable objects, spilling of liquids out of vessels.
- V. *Very strong.* Cracks in the walls, overturning of gravestones, stone lanterns, etc., damage to chimneys and mud-and-plaster warehouses.
- VI. *Disastrous.* Demolition of houses by less than 30%, intense landslides, etc.
- VII. *Very disastrous.* Demolition of houses by more than 30%, intense landslides, large fissures in the ground, faults.

#### 2. SEISMIC INTENSITY SCALE, MEDVEDEV, SPONHEUER & KARNIK (MSK) VERSION, 1964

#### Classification of the Scale

Types of structures (buildings not anti-seismic) -

Structures:

- A: Buildings in field-stone, rural structures, adobe houses, clay houses.
- B: Ordinary brick buildings, buildings of the large block and prefabricated type, half-timbered structures, buildings in natural hewn stone.
- C: Reinforced buildings, well-built wooden structures.

#### Definition of Quantity

|                |       |     |
|----------------|-------|-----|
| Single, a few: | about | 5%  |
| Many:          | about | 10% |
| Most           | about | 75% |

#### Classification of Damage to Buildings

- |          |                  |  |
|----------|------------------|--|
| Grade 1: | Slight damage.   | Fine cracks in plaster; fall of small pieces of plaster.   |
| Grade 2: | Moderate damage. | Small cracks in walls; fall of fairly large pieces of plaster; pantiles slip off; cracks in chimneys; parts of chimneys fall down. |

|          |   |  |
|----------|---|--|
| Grade 3: | Heavy damage. Large and deep cracks in walls; fall of chimneys. |  |
| Grade 4: | Destruction.  | Gaps in walls; parts of buildings may collapse; separate parts of the building lose their cohesion; inner walls and filled-in walls of the frame collapse. |
| Grade 5: | Total damage.   | Total collapse of buildings.   |

### Arrangement of the Scale

- (a) Persons and surroundings
- (b) Structures of all kinds
- (c) Nature

### Intensity Grades

#### I. Not noticeable

The intensity of the vibration is below the limit of sensibility; the tremor is detected and recorded by seismographs only.

#### II. Scarcely noticeable (very slight)

Vibration is felt only by individual people at rest in house, especially on upper floors of buildings.

#### III. Weak, partially observed only

The earthquake is felt indoors by a few people, outdoors only in favorable circumstances. The vibration is like that due to the passing of a light truck. Attentive observers notice a slight swinging of hanging objects, somewhat more heavily on upper floors.

#### IV. Largely observed

The earthquake is felt indoors by many people, outdoors by a few. Here and there people awake, but no one is frightened. The vibration is like that due to the passing of a heavily loaded truck. Windows, doors and dishes rattle. Floors and walls creak. Furniture begins to shake. Hanging objects swing slightly. Liquids in open vessels are slightly disturbed. In standing motor cars the shock is noticeable.

#### V. Awakening

(a) The earthquake is felt indoors by all, outdoors by many. Many sleeping people awake. A few run outside. Animals become uneasy. Buildings tremble throughout. Hanging objects swing considerably. Pictures knock against walls or swing out of place. Occasionally pendulum clocks stop. Unstable objects may be overturned or shifted. Open doors and windows are thrust open and slam back again. Liquids spin in small amounts from well-filled open containers. The sensation of vibration is like that due to a heavy object falling inside the buildings.

(b) Slight damage of Grade I in buildings of Type A is possible.

(c) Sometimes change in flow of springs.

## VI. Frightening

(a) Felt by most, indoors and outdoors. Many people in buildings are frightened and run outdoors. A few persons lose their balance. Domestic animals run out of their stalls. In a few instances dishes and glassware may break, books fall down. Heavy furniture may possibly move and small steeple bells may ring.

(b) Damage of Grade 1 is sustained in single buildings of Type B and in many of Type A. Damage in a few buildings of Type A is of Grade 2.

(c) In a few cases cracks up to widths of 1 cm possible in wet ground; in mountains occasional landslides; changes in flow of springs and in level of well-water are observed.

## VII. Damage to buildings

(a) Most people are frightened and run outdoors. Many find it difficult to stand. The vibration is noticed by persons driving motor cars.

(b) In many buildings of Type C damage of Grade 1 is caused; in many buildings of Type B damage is of Grade 2. Many buildings of Type A suffer damage of Grade 3 and a few of Grade 4. In single instances landslips of roadway on steep slopes; cracks in roads; seams of pipelines damaged; cracks in stone walls.

(c) Waves are formed on water and water is made turbid by mud stirred up. Water levels in wells change and flow of springs change. In a few cases dry springs have their flow restored and existing springs stop flowing. In isolated instances parts of sandy or gravelly banks slip off.

## VIII. Destruction of buildings

(a) Fright and panic; also persons driving motor cars are disturbed. Here and there branches of trees break off. Even heavy furniture moves and partly overturns. Hanging lamps are in part damaged.

(b) Many buildings of Type C suffer damage of Grade 2, a few of Grade 3. Many buildings of Type B suffer damage of Grade 3 and a few of Grade 4 and many buildings of Type A suffer damage of Grade 4 and a few of Grade 5. Occasional breakage of pipe seams. Memorials and monuments move and twist. Tombstones overturn. Stone walls collapse.

## IX. General Damage to Buildings

(a) General panic; considerable damage to furniture. Animals run to and fro in confusion and cry.

(b) Many buildings of Type C suffer damage of Grade 3, a few of Grade 4. Many buildings of Type B show damage of Grade 4, a few of Grade 5. Many buildings of Type A suffer damage of Grade 5. Monuments and columns fall. Considerable damage to reservoirs; underground pipes partly broken. In individual cases railway lines are bent and roadways damaged.

(c) On flat land, overflow of water, sand and mud is often observed. Ground cracks to widths of up to 10 cm, on slopes and river banks more than 10 cm; furthermore a large number of slight cracks in ground; falls of rock, many landslides and earth flows; large waves on water. Dry wells renew their flow and existing wells dry up.

## X. General Destruction of Buildings

(a) Many buildings of Type C suffer damage of Grade 4, a few of Grade 5. Many buildings of Type B show damage of Grade 5; most of Type A have destruction Category 5; critical damage to dams and dykes and severe damage to bridges. Railway lines are bent slightly. Underground pipes are broken or bent. Road paving and asphalt show waves.

(b) In ground, cracks up to widths of more than 10 cm, sometimes up to 1 m. Broad fissures occur parallel to water courses. Loose ground slides from steep slopes. From riverbanks and steep coasts considerable landslides are possible. In coastal areas displacement of sand and mud; change of water level in wells; water from canals, lakes, rivers, etc., thrown on land. New lakes occur.

## XI. Catastrophe

(a) Severe damage even to well built buildings, bridges, water dams and railway lines; highways become useless; underground pipes destroyed.

(b) Ground considerably distorted by broad cracks and fissures, as well as by movement in horizontal and vertical directions, numerous landslips and falls of rock.

The intensity of earthquake requires to be investigated in a special way.

## XII. Landscape Changes

(a) Practically all structures above and below ground are greatly damaged or destroyed.

(b) The surface of the ground is radically changed. Considerable ground cracks with extensive vertical and horizontal movements are observed. Fall of rock and slumping of riverbanks over wide areas; lakes are dammed; and rivers are deflected.

The intensity of the earthquake requires to be investigated in a special way.

## 3. MODIFIED MERCALLI INTENSITY SCALE, 1956 VERSION

### Classification of Masonry

Masonry A, B, C, D. To avoid ambiguity of language, the quality of masonry, brick or otherwise, is specified by the following lettering (which has no connection with the conventional Class A, B, C construction).

Masonry A. Good workmanship, mortar and design; reinforced, especially laterally, and bound together by using steel, concrete, etc.; designed to resist lateral forces.

Masonry B. Good workmanship and mortar; reinforced, but not designed in detail to resist lateral forces.

Masonry C. Ordinary workmanship and mortar; no extreme weaknesses like failing to tie in at corners, but neither reinforced nor designed against horizontal forces.

Masonry D. Weak materials, such as adobe, poor mortar, low standards of workmanship, weak horizontally.

## Intensity Grades

- I. Not felt. Marginal and long period of large earthquakes.
- II. Felt by persons at rest, on upper floors, or favorably placed.
- III. Felt indoors. Hanging objects swing. Vibration like passing of light trucks. Duration estimated. May not be recognized as an earthquake.
- IV. Hanging objects swing. Vibration like passing of heavy trucks; or sensation of a jolt like a heavy ball striking the walls. Standing motorcars rock. Windows, dishes, doors rattle. Glasses clink. Crockery clashes. In the upper range of Grade IV, wooden walls and frames crack.
- V. Felt outdoors; direction estimated. Sleepers wakened. Liquids disturbed, some spilled. Small unstable objects displaced or upset. Doors swing, close, open. Shutters, pictures move. Pendulum clocks stop, start, change rate.
- VI. Felt by all. Many frightened and run outdoors. Persons walk unsteadily. Windows, dishes, glassware broken. Knickknacks, books, and so on, off shelves. Pictures off walls. Furniture moved or overturned. Weak plaster and Masonry D cracked. Small bells ring (church, school). Trees, bushes shaken visibly or heard to rustle.
- VII. Difficult to stand. Noticed by drivers of motorcars. Hanging objects quiver. Furniture broken. Damage to Masonry D including cracks. Weak chimneys broken at roof line. Fall of plaster, loose bricks, stones, tiles, cornices, unbraced parapets, and architectural ornaments. Some cracks in Masonry C. Waves on ponds; water turbid with mud. Small slides and caving in and along sand or gravel banks. Large bells ring. Concrete irrigation ditches damaged.
- VIII. Steering of motorcars affected. Damage to Masonry C; partial collapse. Some damage to Masonry B; none to Masonry A. Fall of stucco and some masonry walls. Twisting, fall of chimneys, factory stacks, monuments, towers, elevated tanks. Frame houses moved on foundations if not bolted down; loose panel walls thrown out. Decayed piling broken off. Branches broken from trees. Changes in flow or temperature of springs and wells. Cracks in wet ground and on steep slopes.
- IX. General panic. Masonry D destroyed; Masonry C heavily damaged, sometimes with complete collapse; Masonry B seriously damaged. General damage to foundations. Frame structures, if not bolted, shifted off foundations. Frames racked. Conspicuous cracks in ground. In alleviated areas sand and mud ejected, earthquake fountains, sand craters.
- X. Most masonry and frame structures destroyed with their foundations. Some well built wooden structures and bridges destroyed. Serious damage to dams, dikes, embankments. Large landslides. Water thrown on banks of canals, rivers, lakes, etc., and mud shifted horizontally on beaches and flat land. Rails bent slightly.
- XI. Rails bent greatly. Underground pipelines completely out of service.
- XII. Damage nearly total. Large masses displaced. Lines of sight and level distorted. Objects thrown into the air.

## APPENDIX B

### GRS SAFETY CODES AND GUIDES

The shocks induced by the aircraft impact shall be considered. This may be done<sup>[1]</sup> in the following way:

The stability of components or systems in the reactor building not supported by outside walls or arranged at ceilings separated from outside walls and/or the base plate may be demonstrated by assuming an equivalent static load resulting from an acceleration of  $\pm 0.5$  in horizontal or vertical direction in the frequency range up to 16 Hz. In the frequency range exceeding 16 Hz it must be assumed that relative motions up to 1mm, with respect to the component and the support, may be absorbed elastoplastically.

---

<sup>[1]</sup> Note:

Condition for the admissibility of the described demonstration method is that the reactor buildings do not vary essentially in the following points from the reactor building of the NPP Grohnde, for which the admissibility of the method had been demonstrated:

- ceilings and walls in the reactor building being separated from the outside walls
- wall thickness and reinforcement of the outside walls
- concrete quality
- total weight
- outside diameter
- binding depth into the foundation soil
- foundation soil conditions (the influence of soil attenuation is low). Only in case of extreme foundation conditions is pile or rock foundation the admissibility of the application of the simplified demonstration method shall be demonstrated.

For types of construction different from KWU-pressurized water reactors of the Nuclear Power Plant Grohnde type and following as well as for other buildings to be protected than the reactor building, the value of the equivalent static load shall be determined by experts when using the simplified demonstration method.

TABLE 1 TYPICAL PEAK GROUND ACCELERATIONS CORRELATED WITH INTENSITY SCALES

| PGA (g) | MODIFIED MERCALLI | MSK-64 INTENSITY |
|---------|-------------------|------------------|
| >0.025  | ≤ IV              | ≤ IV             |
| 0.025   | V                 | V                |
| 0.05    | VI                | VI               |
| 0.10    | VII               | VII              |
| 0.20    | VIII              | VIII             |
| 0.40    | IX                | IX               |
| >0.40   | X                 | X                |

TABLE 2 FACILITY CLASSIFICATION IN JAPAN AS A FUNCTION OF A SEISMIC IMPORTANCE

|          |  |
|----------|--|
| Class As | Facilities, damage of which may cause loss of coolant; facilities, which are required for emergency shutdown of the nuclear reactor and are needed to maintain the shutdown state of the reactor in a safe state; facility for storage of spent fuel; and nuclear reactor containment. |
| Class A  | Facilities, which are needed to protect the public from the radioactive hazard in the case of a nuclear reactor accident, and facilities, malfunction of which may cause radioactive hazard to the public, but are not classified as Class As.   |
| Class B  | Facilities, which are related to the highly radioactive substance, but are not classified as Class As and Class A.   |
| Class C  | Facilities, which are related to the radioactive substance, but are not classified in the above aseismic classes, and facilities not related to radioactive safety.  |

TABLE 3 CORRESPONDENCE BETWEEN ASEISMIC IMPORTANCE OF FACILITY AND BASIC EARTHQUAKE GROUND MOTION, STATIC SEISMIC COEFFICIENT, ETC. IN JAPAN<sup>(1,2)(11)</sup>

|                                       | Aseismic Importance                        | Basic earthquake ground motion, story shear coefficient, static seismic coefficient | Horizontal <sup>(5,6,7)</sup>  | Vertical <sup>(8,9,10)</sup> |
|---------------------------------------|--|---|--------------------------------|------------------------------|
| Building/<br>Structure <sup>(3)</sup> | As   | Basic earthquake ground motion  | $A_{S2}$                       | $\frac{1}{2} A_{S2}$         |
|                                       | As, A                                      | Basic earthquake ground motion  | $A_{S1}$                       | $\frac{1}{2} A_{S1}$         |
|                                       |  | Story shear coefficient, Static seismic coefficient                                 | $3.0 C_1$                      | $C_V$                        |
|                                       | B  | Basic earthquake ground motion  | ---                            | ---                          |
|                                       |  | Story shear coefficient   | $1.5 C_1$                      | ---                          |
|                                       | C  | Basic earthquake ground motion  | ---                            | ---                          |
|                                       |  | Story shear coefficient   | $C_1$                          | ---                          |
|                                       | Equipment/<br>Piping System <sup>(4)</sup> | As  | Basic earthquake ground motion | $A_{S2}$                     |
| As, A                                 |  | Basic earthquake ground motion  | $A_{S1}$                       | $\frac{1}{2} A_{S1}$         |
|                                       |  | Static seismic coefficient  | $3.6 C_1$                      | $1.2 C_V$                    |
| B                                     |  | Basic earthquake ground motion  | ---                            | ---                          |
|                                       |  | Static seismic coefficient  | $1.8 C_1$                      | ---                          |
| C                                     |  | Basic earthquake ground motion  | ---                            | ---                          |
|                                       | Static seismic coefficient                 | $1.2 C_1$   | ---                            |                              |

- (1) For Class  $A_S$  and Class A facilities, the horizontal seismic force and the vertical seismic force due to the basic earthquake ground motion are combined both in the unfavorable direction; and the horizontal seismic force and vertical seismic force caused by the story shear coefficient or the static seismic coefficient are combined in the unfavorable direction.
- (2) The static horizontal seismic force of the underground portion of the building/structure is calculated by the horizontal seismic coefficient  $K$  specified for the underground portion. The static horizontal seismic force of the underground portion of the equipment/piping system is calculated from the value 20% larger than the horizontal seismic coefficient of the building/structure at the location where said equipment is set.
- (3) For building/structure, the horizontal seismic force is calculated from the story shear coefficient; the vertical seismic force is calculated from the vertical seismic coefficient.
- (4) The static horizontal seismic force of the equipment/piping system is calculated by regarding the story shear coefficient of the structure at the location of mounting as the seismic coefficient.
- (5)  $A_{S2}$ : Acceleration acting on the facility due to basic earthquake ground motion  $S_2$ .
- (6)  $A_{S1}$ : Acceleration acting on the facility due to basic earthquake ground motion  $S_1$ .
- (7)  $C_1$ : Story shear coefficient.
- (8)  $C_V$ : Vertical seismic coefficient for calculating static seismic force.
- (9)  $\frac{1}{2} A_{S2}$ :  $\frac{1}{2}$  the value of the maximum acceleration amplitude of basic earthquake ground motion  $S_2$  is taken as the vertical seismic coefficient.
- (10)  $\frac{1}{2} A_{S1}$ :  $\frac{1}{2}$  the value of the maximum acceleration amplitude of basic earthquake ground motion  $S_1$  is taken as the vertical seismic coefficient.
- (11) Until recently Japanese NPP seismic design has applied vertical seismic motion as an equivalent static coefficient not as a vertical response spectra.

TABLE 4 COMPARISON OF ONE-DEGREE-OF-FREEDOM MAXIMUM AMPLIFICATION FACTORS FOR HORIZONTAL<sup>(1)</sup> SOIL BASED SEISMIC RESPONSE TO PEAK GROUND MOTION FOR VARIOUS DAMPING VALUES AND GENERIC RESPONSE SPECTRA

| % critical damping | Weighted Average Housner |      |        | R.G. 1.60 Horizontal, Median <sup>(2,3)</sup> Plus One Standard Deviation |      |          | NUREG/CR-0098 Horizontal Median Soil |      |        | DOE-GIP Reference Spectra |      |        |
|--------------------|--------------------------|------|--------|---|------|----------|--------------------------------------|------|--------|---------------------------|------|--------|
|                    | Accel.                   | Vel. | Displ. | Accel.  | Vel. | Displ.   | Accel.                               | Vel. | Displ. | Accel.                    | Vel. | Displ. |
| 0.5                | 6.2                      | 2.7  | 1.4    | 5.95  | 3.7  | 3.2      | 3.68                                 | 2.59 | 2.01   |                           |      |        |
| 1                  | 4.6                      | --   | --     | --  | --   | --       | 3.21                                 | 2.31 | 1.82   |                           |      |        |
| 2                  | 3.1                      | --   | --     | 4.25  | 3.2  | 2.5      | 2.74                                 | 2.03 | 1.63   |                           |      |        |
| 5                  | 2.3                      | 1.6  | 1.2    | 3.13  | 2.4  | 2.0<br>5 | 2.12                                 | 1.65 | 1.39   | 2.14 <sup>(5)</sup>       |      |        |
| 7                  | 1.5                      | 1.3  | 1.0    | 2.72  | 2.1  | 1.8<br>8 | 1.89                                 | 1.51 | 1.29   |                           |      |        |
| 10                 | --                       | --   | --     | 2.28  | 1.8  | 1.7<br>0 | 1.64                                 | 1.37 | 1.20   |                           |      |        |
| 20                 | --                       | --   | --     | --  | --   | --       | 1.17                                 | 1.08 | 1.01   |                           |      |        |

Based on a standard deviation relative earthquake maximum values of ground motion,

- Acceleration = 0.10g,
- Velocity = 4.8 in/sec,
- Displacement = 3.6 in.

- (2) For vertical motion slightly different amplification values are defined.
- (3) Since a normal distribution was assumed, the median equals the mean for the density function assumed.
- (4) More recent earthquake data suggests a log-normal distribution of earthquake amplification is appropriate. The mean of the log-normal distribution is approximately equal (85 percentile) to the mean or median of the normal distribution plus one standard deviation.
- (5) Peak spectral accelerations are at 40-50 Hz for CEUS recorded earthquakes while WUS recorded earthquakes maximum spectral accelerations occur at 2 to 8 Hz. Peak CEUS earthquakes accelerations occur at spectral displacement values which typically do not cause damage to mechanical-civil structures.

TABLE 5 TYPICAL DAMPING FACTORS (PERCENT CRITICAL) USED IN DESIGN OF STRUCTURES, MECHANICAL AND ELECTRICAL EQUIPMENT AND DISTRIBUTION SYSTEMS

| MATERIAL                         | HOUSNER | U.S. NRC<br>R.G. 1.61 |                    | NUREG/CR-0098 |      | DOE-GIP<br>Ref. Spectra |
|----------------------------------|---------|-----------------------|--------------------|---------------|------|-------------------------|
|                                  |         | OBE                   | SSE                | OBE           | SSE  | RLE                     |
| <b>Structures<sup>(1)</sup>:</b> |         |                       |                    |               |      |                         |
| Reinforced Concrete              | 5.0     | 4.0                   | 7.0                | 5.0           | 7.0  | 7.0                     |
| Pre-stressed Concrete            | 2.0     | 2.0                   | 5.0                | 5.0           | 5.0  | 5.0                     |
| Bolted Steel                     | 2.0     | 4.0                   | 7.0                | 5.0           | 10.0 | 10.0                    |
| Welded Steel                     | 1.0     | 2.0                   | 4.0                | 2.0           | 5.0  | 5.0                     |
|                                  |         |                       |                    |               |      |                         |
| <b>Distribution Systems:</b>     |         |                       |                    |               |      |                         |
| Piping                           | 0.5     | 2.0                   | 3.0 <sup>(2)</sup> | 2.0           | 5.0  | 5.0                     |
| Conduit                          | 0.5     | 2.0                   | 3.0                | 2.0           | 5.0  | 5.0                     |
| Ductwork                         | 0.5     | 2.0                   | 3.0                | 2.0           | 5.0  | 5.0                     |
| Tubing                           | 0.5     | 1.0                   | 2.0                | 2.0           | 5.0  | 5.0                     |
| Cable Trays                      | 2.0     |                       |                    | 5.0           | 10.0 | 10.0                    |
|                                  |         |                       |                    |               |      |                         |
| <b>Equipment:</b>                |         |                       |                    |               |      |                         |
| Tanks                            |         |                       |                    |               |      |                         |
| Impulse                          | 3.0     | 3.0                   | 3.0                | 3.0           | 3.0  | 3.0                     |
| Sloshing                         | 0.5     | 0.5                   | 0.5                | 0.5           | 0.5  | 0.5                     |
| Components                       |         |                       |                    |               |      |                         |
| Mechanical                       | 1.0     | 2.0                   | 4.0                | 2.0           | 5.0  | 5.0                     |
| Electrical                       | 1.0     | 2.0                   | 4.0                | 2.0           | 5.0  | 3.0                     |
|                                  |         |                       |                    |               |      |                         |
|                                  |         |                       |                    |               |      |                         |
|                                  |         |                       |                    |               |      |                         |

(1) Building damping, when determining floor or amplified response spectra, is dependent on stress levels. For building stress levels below 0.8 yield use 4.0 percent; above 0.8 yield use 7 percent.

(2) For piping less than 12 inches in diameter dampings of 1.0 and 2.0 percent critical for OBE and SSE respectively were specified.

TABLE 6: ESTIMATED DIRECT COST (IN 2000 U.S. DOLLARS) OF AN 1100-1300-MWe LIGHT WATER REACTOR PLANT CONSTRUCTED IN THE U.S. WITH NATURAL DRAFT EVAPORATIVE COOLING TOWERS FROM START OF PROJECT TO COMMERCIAL OPERATION (120 MONTHS) INCLUDING A 0.2 TO 0.3G SSE PEAK GROUND ACCELERATION USING DIRECT SEISMIC DESIGN REQUIREMENT

| ACCOUNT  | SEISMIC <sup>(2)</sup><br>COST | TOTAL<br>COST |
|--|--------------------------------|---------------|
| DIRECT COST IN MILLIONS                          |                                |               |
| Land and land rights                             |                                | 4             |
| Site specific seismic studies-spectra generation | 2.0                            | 2             |
| Soil site foundation media improvement           | 8.0                            | 8             |
| Sub-Total  | 10.0                           | 14            |
| Physical plant:                                  |                                |               |
| Safety Class – Seismic Category I Structures     | 4.2                            | 82            |
| Non-Safety Class Structures                      | --                             | 50            |
| Reactor plant equipment <sup>(1)</sup>           | 11.0                           | 288           |
| Turbine plant equipment                          | --                             | 250           |
| Electric plant equipment <sup>(1)</sup>          | 10.2                           | 102           |
| Spent fuel and nuclear waste storage             | 3.0                            | 55            |
| Miscellaneous plant equipment (cooling tower)    | --                             | 54            |
| Sub-Total  | 28.4                           | 881           |
| Spare parts allowance                            | --                             | 5             |
| Contingency allowance                            | 5.0                            | 100           |
| Sub-Total  | 5.0                            | 105           |
| Distribution Systems                             |                                |               |
| Piping   | 105.0                          | 250           |
| Cable Trays and Conduit                          | 4.0                            | 40            |
| Duct   | 1.0                            | 8             |
| Sub-Total  | 110.0                          | 298           |
| Direct Overhead Costs                            |                                |               |
| Regulatory and licensing                         | 1.0                            | 15            |
| Construction facilities, equipment and services  | --                             | 84            |
| A/E engineering conceptual and detailed design   | 40.0                           | 335           |
| A/E engineering support during construction      | 4.0                            | 65            |
| Construction management services                 | --                             | 58            |
| Start-up costs                                   | --                             | 38            |
| Sub-Total  | 45.0                           | 595           |
| Cost at Commercial Operation                     |                                |               |
| TOTAL  | 198.4                          | 1893.0        |

(1) Approximately two-thirds of the total is safety related.

(2) For a 0.2 – 0.3g pga soft soil site.

TABLE 7: ESTIMATED DIRECT COST (IN 2000 U.S. DOLLARS) OF AN 1100-1300-MWe LIGHT WATER REACTOR PLANT CONSTRUCTED IN THE U.S. WITH NATURAL DRAFT EVAPORATIVE COOLING TOWERS FROM START OF PROJECT TO COMMERCIAL OPERATION (120 MONTHS) INCLUDING A 0.2 TO 0.3G SSE PEAK GROUND ACCELERATION USING INDIRECT SEISMIC DESIGN REQUIREMENT

| <b>ACCOUNT</b>                                   | <b>SEISMIC<sup>(2)</sup><br/>COST</b> | <b>TOTAL<br/>COST</b> |
|--|---------------------------------------|-----------------------|
| <b>DIRECT COST IN MILLIONS</b>                   |                                       |                       |
| Land and land rights                             |                                       | 4                     |
| Site specific seismic studies-spectra generation | 2.0                                   | 2                     |
| Soil site foundation media improvement           | 8.0                                   | 8                     |
| Sub-Total  | 10.0                                  | 14                    |
| Physical plant:                                  |                                       |                       |
| Safety Class – Seismic Category I Structures     | 4.2                                   | 82                    |
| Non-Safety Class Structures                      | --                                    | 50                    |
| Reactor plant equipment <sup>(1)</sup>           | 5.0                                   | 282                   |
| Turbine plant equipment                          | --                                    | 250                   |
| Electric plant equipment <sup>(1)</sup>          | 7.2                                   | 99                    |
| Spent fuel and nuclear waste storage             | 1.0                                   | 54                    |
| Miscellaneous plant equipment (cooling tower)    | --                                    | 54                    |
| Sub-Total  | 13.2                                  | 871                   |
| Spare parts allowance                            |                                       |                       |
|  | --                                    | 5                     |
| Contingency allowance                            |                                       |                       |
|  | 3.0                                   | 97                    |
| Sub-Total  | 3.0                                   | 102                   |
| Distribution Systems                             |                                       |                       |
| Piping   | 40.0                                  | 145                   |
| Cable Trays and Conduit                          | 3.0                                   | 37                    |
| Duct   | 1.0                                   | 8                     |
| Sub-Total  | 44.0                                  | 190                   |
| Direct Overhead Costs                            |                                       |                       |
| Regulatory and licensing                         | 1.0                                   | 15                    |
| Construction facilities, equipment and services  | --                                    | 84                    |
| A/E engineering conceptual and detailed design   | 8.0                                   | 303                   |
| A/E engineering support during construction      | 4.0                                   | 65                    |
| Construction management services                 | --                                    | 58                    |
| Start-up costs                                   | --                                    | 38                    |
| Sub-Total  | 13.0                                  | 563                   |
| Cost at Commercial Operation                     |                                       |                       |
| TOTAL  | 82.7                                  | 1740                  |

(1) Approximately two-thirds of the total is safety related.

(2) For a 0.2 – 0.3g pga soft soil site.




Figure 1: MAP OF THE UNITED STATES SHOWING ZONES OF PROXIMATELY EQUAL SEISMIC PROBABILITY  
 As approved by the International Conference of Building Officials at the twenty-eighth Annual Meeting. This map of seismic probability is legally apart of this code.




Figure 2: Housner Type Horizontal Type Spectra




Figure 3: Horizontal Design Response Spectra in IAEA Safety Guide 1975 Edition




Figure 4: NUREG/CR-0098 Median Ground Response Spectrum for a Soil Site




Figure 5: Absolute response spectra (5% of critical damping) computed for M=6.5 at R=25 km using both single and double-corner frequency source spectra for WUS and CEUS conditions.

# TYPICAL FLOOR SPECTRUM B TO BE USED IN EVALUATING SEISMIC RESPONSE OF PIPING

0.1875g ZPA and 7% Building and 5% Piping Damping (Bldg. Mid. Height for 0.1g ZPGA)




Figure 6: Second Approach Representative Floor Spectra Used in the Study – Rock Site (Rock Spectra)

# TYPICAL FLOOR SPECTRUM A TO BE USED IN EVALUATING SEISMIC RESPONSE OF PIPING

0.1875g ZPA and 7% Building and 5% Piping Damping (Bldg. Mid. Height for 0.1g ZPGA)




Figure 7: Second Approach Representative Floor Spectra Used in the Study – Soil Site (Soil Spectra)






Figure 8: No-Cracking Response Spectra ( $\beta=0.03$ ) ( After Dowding, 1971)




(a)

Single Lumped Mass Model with Spring Supports




(b)

Single Lumped Mass Model with Fixed Support



(c)

Multi-Degree-of-Freedom Lumped Masses Connected by 6x6 Stiffness Matrixes on a Fixed Base



(d)

Multi-Degree-of-Freedom Lumped Masses Connected by 6x6 Stiffness Matrixes on a Spring Base




Figure 9: Typical Lumped Mass Models





Figure 10: Lumped Mass 3-D Model with Center of Mass Displaced from Center of Shear




Figure 11: Best Estimate Seismic Cost Increase for Constructing Between 2000 and 2010 Based on Direct Methods of Seismic Evaluation