



Adaptation of the Modern Approaches for Protection of Nuclear Power Plants against the Effects of Postulated Pipe Ruptures to the Russian National Guides. Problems and Experience.

Alexei Berkovsky¹⁾, Victor Kostarev¹⁾, John D. Stevenson²⁾

¹⁾ CKTI-Vibroseism, St. Petersburg, Russian Federation

²⁾ J.D. Stevenson, Consulting Engineer, Cleveland, Ohio, USA

ABSTRACT

Requirements for protection of Nuclear Power Plants against postulated ruptures of High-Energy Piping systems present practically in all National and International Guidelines for NPP Safety Design.

Basically this problem consists of three general parts:

- 1) location of postulated ruptures;
- 2) consideration of the pipe rupture's consequences;
- 3) realization of the protective measures.

Presented paper describes the evolution and contemporary state of the problem regarding existing WWER NPPs in East Europe and Russia, as well as implementation of the High Energy Line Breaks (HELB) Analysis for the new-designed WWER Units.

Paper presents the analysis of the current Russian National Guides regarding High Energy Line Breaks (HELB) problem. On the basis of this analysis the proposals for entering in Russian National Guide documentation changes and additions are developed.

A special emphasis is given on the formulation of the intermediate rupture's locations based on the Strength Analysis according to PNAE G-7-002-86 (Russian Code) stress equations.

The numerical comparative PNAE-ASME Analysis has been performed to illustrate the main approaches of the proposed methodology.

KEY WORDS: High Energy Piping, postulated pipe rupture, piping stress analysis, rupture's consequences, nuclear, power plants, internal hazard, HELB, PNAE, ASME, WWER, rupture protection, pipe whip.

INTRODUCTION

According to the international practice an acceptable Safety level for the new-designed as well as existing Nuclear Power Plants should be achieved by means of all-sided sophisticated assessment of all types of internal and external hazards that may directly affect on the Public Safety of Nuclear Installations. From this point of view a phenomena of high energy piping rupture should be considered as one of the internal hazard postulated initiating event (PIE) and requires assessments of its direct and secondary effects, such as: compartment's pressurization, pipe whip, jet impingement, missiles generation, flooding and unacceptable environmental effects. Basically, this problem may be considered as consisted from three general parts: postulating of rupture locations, consideration of break's consequences and providing of break-resistant design. Recently issued by IAEA draft Safety Guide "Protection against Internal Hazards Other than Fire and Explosions", [1] introduces the probabilistic and deterministic approaches for reviewing:

- PIEs, postulated in a deterministic approach, and the probability of occurrence of which is estimated in the probabilistic approach,
- potential or probability to affect structures, systems and components (SSCs),
- potential or probability of damaging consequences overall assessment of consequences, in order to judge on their acceptability.

Although pipe ruptures could result from a wide range of random events, such as specific loading and environmental conditions, manufacturing quality, etc., finally, the piping failure is assumed to be governed by the local conditions of stress and fatigue. An alternative to the deterministic approach for HELB analysis is implementation of Probabilistic Risk Assessment procedure to define location of possible pipe ruptures and probabilistic-based assessment for consequences of these ruptures. The main advantage of such procedures are the cost-effective approaches for consideration of only limited number of High Energy piping having an essential high probability of ruptures and which are capable to influence on the safety-related SSC. However, use of such analyses should be based on the comprehensive databases with systematically processed data for registered piping failures, load conditions, specific materials and so on. In the absence of such data an expensive fracture-mechanic analyses may be performed that again requires the representative statistic of piping failures. Quite appropriate for the "case by case" implementation this

procedure is hardly may be used as design basis tool. That is why the main focus of the presented paper is made on the deterministic approach for postulating of pipe rupture.

An attempt to accommodate and harmonize the main approaches of HELB procedure based on the international experience to the Russian National Guides is made by consideration of specific peculiarities of Russian Strength Guide PNAE G-7-002-86 [2] regarding to stress and fatigue requirements for postulating of intermediate piping rupture locations.

DEVELOPMENT AND CURRENT STATE OF THE HELB PROBLEM

The problem of Nuclear Power Plants protection against the consequences of postulated ruptures of High Energy piping appeared in the design process starting from the middle sixties – practically from the time of first industry nuclear installations. Initially, consideration of this problem was limited by analysis of Loss of Coolant Accident (LOCA) – Double Ended Guillotine Break (DEGB) of Primary Circuit Piping with release of High Energy Medium. The main concern of this consideration was an integrity of Reactor Containment under pressure, fluid jet and missile effects associated with Primary Coolant Line's break. However, once such phenomena was postulated there was a subsequent requirements for consideration of all other relevant effects of postulated pipe ruptures other than Reactor Containment capacity. Gradually the list of the High Energy Piping was expanded for all piping having operating temperature more than 100°C or/and Internal Pressure greater then 2 MPa not only inside but also outside Containment area. The first Regulatory Guide – NRC RG 1.46 [3] starting from 1973 has installed the main approaches for the design basis for protection against pipe whip inside Containment. Later, the detailed criteria for pipe breaks both inside and outside Containment were developed in Standard Review Plan Sections 3.6.1 and 3.6.2 [4, 5]. In the eighties two revisions of American National Standard ANSI/ANS-58.2 "Design Basis for Protection of Light Water Nuclear Power Plants against the Effects of Postulated Pipe Rupture" have been issued in 1980 and 1988. The last edition (1988) of this document has reflected recent changes in the HELB design philosophy that were induced by development of Leak Before Break (LBB) approach. In several points this document installed a less restrictive than NRC requirements:

- Standard allowed application of LBB to any point on a given run of pipe where the rupture locations have been postulated (NRC required LBB application to all points including the end points at each anchor);
- Standard allowed consideration of the environmental and flooding effects based on the reduced flow rate from a leakage crack (NRC required consideration of flow rates from the full-size ruptures);
- For postulated break locations in ASME Class I piping Standard proposed the value of 0.4 for the fatigue usage factor (versus the NRC value 0.1);
- Standard installed less conservative than NRC stress threshold criteria for postulating intermediate breaks in Class I piping not in the containment penetration area.

The current practice of HELB analysis considers the following types of piping ruptures:

- circumferential break – pipe severance with full separation of the two severed pipe ends;
- longitudinal break – a split of the pipe wall along the pipe longitudinal axis, but without severance;
- throw-wall crack – a circular orifice through the pipe wall;
- leakage crack – crack through the pipe wall where the size of the crack and corresponding flow rate are determined by LBB based analysis.

There are two approaches for determination of postulated ruptures locations and configurations:

- "a priori" approach, when locations of postulated ruptures are defined for all terminal ends + intermediate locations of potential high stress or fatigue such as pipe fittings, valves, flanges and welded-on attachments;
- "by analysis" approach, when location of postulated ruptures are defined again for the all terminal ends + intermediate locations where stress and fatigue conditions exceed prescribed threshold values.

Once the locations of piping ruptures were determined then the primary objectives following a postulated pipe ruptures are to bring and maintain the plant in a safe shut down condition and to assure no further degrading of engineered safety systems. From this point of view the following consequences of pipe ruptures shall be considered and analyzed:

- compartment pressurization effects;
- jet impingement effects;
- pipe whip and pipe internal load effects;
- generation of flying parts (missiles) effects;
- environmental effects;
- flooding effects.

If consideration of all these effects demonstrates a non-exceeding of design allowances, then considered high energy system may be treated as verified. Otherwise, the special protective measures should be implemented to achieve a necessary level of safety. Generally, the best way to provide protection against pipe rupture is a physical separation of high energy piping systems between each other and from the safety-related components. Obviously, such measures may be implemented only during stage of NPP design. If such actions are not appropriate, then it should be tried to relocate essential target or reroute piping postulated to rupture. If, at last, all these recommendations could not be implemented,

then a special protective devices may be used. Design practice recognizes a variety of pipe whip restraints, shields, barriers and so on. For example, a specialized pipe whip restraining devices developed by Siemens – Framatom and similar designed restraints by Skoda – Praha were implemented for a number of WWER units in East Europe.

ADAPTATION OF METHODOLOGY TO THE EXISTING RUSSIAN NATIONAL GUIDES

According to the basic normative document of the Russian Federal regulations and rules in the field of use of nuclear energy "General Regulations on Ensuring Safety of Nuclear Power Plants" OPB-88/97 NP-001-97 (PNAE G-01 011-97) "...an efforts should be made to ensure that the estimated probability rate of limiting emergency release did not exceed 10^{-7} per reactor year" (item 1.2.17). According to the defense in-depth concept the NPP shall have safety systems intended for fulfilling the following main safety functions (item 4.1.2):

- reactor scram and maintaining it in subcritical state;
- emergency removal of heat from the reactor;
- confining radioactive substances within the predetermined limits.

Systems or elements important to safety shall be capable of performing their functions within the scope specified in the design with allowance for natural phenomena possible in the NPP site region, external man-induced events peculiar to the site selected for NPP construction and /or on postulated mechanical, thermal, chemical and other effects of design basis accidents (item 4.1.5).

All above mentioned statements make necessary to consider High Energy Line's Break as possible source or postulated initiating event for the Design Basis Accident. However, up to now Russian Federal regulations does not contain such document, that comprehensively covers all nomenclature for High Energy Piping. One exclusion is a Technical Guideline RD 95.10532-96 issued in 1996 "Guideline for determination of shock waves parameters, excessive pressure and jet impingement loads under break of Primary Circuit Piping". However the main emphasis in this documents is made on the specific effects of Primary Circuit Piping break.

The draft of document that should compensate lack of available national documentation is based on the most comprehensive guideline in this field, namely ANSI/ANS-58.2 (edition of 1988). The main efforts for adaptation of this document were made to harmonize terminology and some assumptions to the existing Russian regulation documents. Table 1 shows a brief summary of postulated pipe ruptures, methods for breaks postulating and types of consequences that should be considered for each type of rupture ("+" means that corresponding effects should be analyzed, "-" means that effects associated with given consequence may be left out of consideration).

Table 1. Types of Ruptures, Methods for Postulating and Consequences are considered.

Rupture Configuration	Piping Energy Classification	method for rupture postulating	Consequences						
			pressurization effects	jet impingement effects	pipe whip effects	pipe internal load effects	generation of flying parts (missiles) effects	environmental effects	flooding effects
circumferential break	High Energy Piping System	"a priory" for Terminal Ends by analysis for intermediate locations	+	+	+	+	+	+	+
longitudinal break		by analysis	+	+	+	+	+	+	+
Throw-wall crack	Moderate Energy Piping System	by analysis	-	-	-	-	-	+	+
leakage crack		may be postulated instead of postulated ruptures with use of LBB approach	-	-	-	-	-	+	+

PROCEDURE FOR DETERMINATION OF INTERMEDIATE RUPTURE'S LOCATIONS AND CONFIGURATION

If the general provisions of considered methodology are not essentially differ from the ANSI/ANS prototype approaches, the procedure for determination of rupture's locations requires more detailed consideration due to differences in Piping Stress Analysis performed according to ASME BPVC versus Russian Code PNAE G-7-002-86.

Both, Russian (GAN) and American (NRC) Regulatory Bodies, require classification of NPP piping and equipment on the system quality groups A, B and C and corresponding Safety Classes 1, 2, 3 and 4 depending from the importance of the safety function to be performed. According to Russian Regulatory requirements all safety-related NNP piping should be included in the Safety Class 2, that corresponds to Class 1 and Class 2 in terms of ASME classification. The difference exists also in the seismic category classification (Table 2). Tables 3 and 4 summarize the differences in stress analyses according to ASME BPVC and PNAE Code.

Table 2. NPP Piping and Equipment Classification.

Code	Quality Group	Safety Class	Seismic Category
PNAE	A ¹⁾	1 ¹⁾	I
	B	2	I
	C	3	II
		4 ²⁾	III
ASME	A	1	I ³⁾
	B	2	I ³⁾
	C	3	I ³⁾
	D	4 ²⁾	-

¹⁾ According to PNAE piping systems are not included in the Group A and Class 1.

²⁾ General Industry Requirements are applied for Class 4 elements according to PNAE as well ASME.

³⁾ Seismic Category is defined in accordance with Design Specification

Table 3 Comparison of Load Combinations and stress categories according to ASME BPVC Class 1 and PNAE.

Levels of Service Limits	Load Combination	ASME BPVC (Class 1)		PNAE	
		Equation	Allowable Stresses	Stress Category	Allowable Stresses
Design Conditions	P + W	(9)	1.5 Sm	(σ) ₁ (σ) ₂	[σ] 1.3[σ]
Service Level A	P + T + T1	(10) or (12) and (13)	3.0 Sm	(σ) _{RK}	$\min \left[\left(2.5 - \frac{R_{p0.2}^T}{R_m^T} \right) * R_{p0.2}^T; 2 * R_{p0.2}^T \right]$
	T	(12)	3.0 Sm		
	P + W + T1	(13)	3.0 Sm		
	P + T + T1 + T2	(11), (12)	-	(σ_{aF}) _K	-
Service Level B	P + W + OBE	(9)	$\min(1.8Sm; 1.5Sy)$	(σ) ₁	1.2[σ]
Service Level C	P + W + L _C	(9)	$\min(2.25Sm; 1.8Sy)$	(σ) ₂	1.6[σ]
Service Level D	P + W + SSE	(9)	$\min(3Sm; 2Sy)$	(σ) ₁	1.4[σ]
	P + W + LOCA			(σ) ₂	1.8[σ]

Table 4 Comparison of Load Combinations and stress categories according to ASME BPVC Class 2, 3 and PNAE.

Levels of Service Limits	Load Combination	ASME BPVC (Class 2, 3)		PNAE	
		Equation	Allowable Stresses	Stress Category	Allowable Stresses
Design Conditions	P + W	(8)	1.5 Sh	(σ) ₁ (σ) ₂	[σ] 1.3[σ]
Service Levels A, B	P + W + OBE	(9)	1.8 Sh	(σ) ₁ (σ) ₂	1.2[σ] 1.6[σ]
	T	(10) or	Sa	(σ) _{RK}	$\min \left[\left(2.5 - \frac{R_{p0.2}^T}{R_m^T} \right) * R_{p0.2}^T; 2 * R_{p0.2}^T \right]$
	SAM _{OBE}	(10a) + (11)	3.0 Sc		
	P + W + T		Sh + Sa		
Service Level C	P + W + L _C	(9)	$\min(2.25Sh; 1.8Sy)$	(σ) ₁ (σ) ₂	1.2[σ] 1.6[σ]
Service Level D	P + W + SSE	(9)	$\min(3Sh; 2Sy)$	(σ) ₁	1.4[σ]
	P + W + LOCA			(σ) ₂	1.8[σ]

Basing on this comparative study the following criteria were proposed to determine intermediate rupture locations (Table 5):

Table 5 Stress and Fatigue Limits for Location of Intermediate Postulated Ruptures.

stress and fatigue limits for circumferential or longitudinal break:	$(\sigma)_2^{NOL+OBE} + (\sigma)_{RK}^{max} \geq 0.8[(\sigma)_a^{NOL+OBE} + (\sigma)_a^{RK}]$	(1)
	$U > 0.4$	(2)
stress and fatigue limits for throw-wall crack:	$(\sigma)_2^{NOL+OBE} + (\sigma)_{RK}^{max} \geq 0.4[(\sigma)_a^{NOL+OBE} + (\sigma)_a^{RK}]$	(3)
	$U > 0.2$	(4)

Type of postulated rupture (circumferential or longitudinal break) may be defined with use of the following expressions:

- circumferential break, if $\frac{\sigma_z}{\sigma_\psi} \geq 1.5$;
- longitudinal break, if $\frac{\sigma_\psi}{\sigma_z} \geq 1.5$
- both types of breaks (circumferential or longitudinal) shall be considered if $\frac{2}{3} < \frac{\sigma_z}{\sigma_\psi} < 1.5$

The following load combination shall be used for calculation values of corresponding stress categories:

- $(\sigma)_2$ stresses: Piping Dead and Live weight + internal pressure + OBE + any other loads specified for Abnormal Plant Conditions;
- $(\sigma)_{RK}$ stresses: loads due to system's transient from one service load set to another: thermal expansions and thermal anchor movements, temperature gradient loads, change of service pressure;
- $(\sigma_{af})_K$ stresses (stress amplitudes used for fatigue analysis) : the same loads as for $(\sigma)_{RK}$ stresses + Hydrotest + 50 cycles of OBE.

The principal flow-chart of the proposed procedure is shown in Figure 1. According to this scheme two types of analyses shall be carried out for stress check:

- static analyses: determination of internal loads in piping elements under Mechanical and Thermal Expansion loads;
- dynamic analysis: determination of internal loads in piping elements under Seismic Impact corresponded to OBE level or any other dynamic loads prescribed by Design Specification for Abnormal Plant Conditions.

Calculation of stress intensity values and value of Cumulative Usage Factor U should be done according to PNAE G-7-002-86 Code requirements.

Comparison of allowable stresses used for determination of rupture location according to PNAE versus ASME approach is shown in Fig. 2. The allowable stresses corresponding to PNAE are calculated according to Eq. (1):

$$PNAE = 0.8[(\sigma)_a^{NOL+OBE} + (\sigma)_a^{RK}].$$

For ASME* value the allowable stresses corresponding to ASME NB-3600 (Class 1) Equation 9 for Service Level B were combined with allowances for Equations 10 or 12 –13:

$$ASME^* = 0.8[\min(1.8Sm; 1.5Sy) + 3.0 Sm]$$

Figure 3 demonstrates comparison of fatigue curves according to PNAE and ASME. As it can be seen from these figures both approaches are satisfactory correlate.

ASME – PNAE COMPARATIVE ANALYSIS

A numerical implementation of the described approach is given for the Main Steam Line of WWER-440 Unit. FE model of this piping is shown in Fig. 4. Seismic Excitation for this study was taken corresponding to 7 balls of MSK-64 scale ($ZPGA_{SSE} = 0.1g$). Numerical results were developed using the specialized Analysis Software Code dPIPE HELB [6]. The main analysis results are shown in Fig. 5 and 6. Figure 6 presents comparison between rupture stress ratios calculated according to PNAE and ASME equations, i.e. ratio between combination of calculated stresses and stress limit for circumferential or longitudinal break.




Fig 1. Flow Chart for High Energy Piping Intermediate Postulated Rupture Location Procedure





Fig. 2 Comparison of allowable stresses used for determination of rupture location.





Fig. 3 Comparison of fatigue curves




Fig. 4 FE Model of Main Steam Line




Fig. 5 HELBA analysis results for Main Steam Piping.




Fig. 6 Comparative PNAE – ASME HELB Analysis Results

SUMMARY AND CONCLUSIONS

Methodology based on the American Standard ANSI/ANS-58.2 " Design basis for potential of light water NPP against the effects of postulated pipe rupture" was considered for adaptation to the current Russian Regulatory practice and requirements.

Procedure, developed according to rules and requirements of Russian Code PNAE G-7-002-86 for determination of intermediate postulated High Energy Piping rupture locations was proposed and verified against the analogues approaches of ASME-based ANSI/ANS technique.

NOMENCLATURE

$(\sigma)_1$	- equivalent membrane stresses	$R_{p0,2}^T$	- yield strength at temperature
$(\sigma)_2$	- category of equivalent stresses from combination of membrane and total bending stresses	Sa	- allowable stress (ASME NC-3600)
$(\sigma)_2^{NOL+OBE}$	- stresses of $(\sigma)_2$ category from mechanical and OBE loads	Sh	- material allowable stress at temperature
$(\sigma)_\psi$	- tangential stress in pipe wall	Sm	- allowable design stress intensity
$(\sigma)_{RK}$	- range of equivalent stresses	SSE	- Safe Shutdown Earthquake
$(\sigma)_Z$	- longitudinal stress in pipe wall	Sy	- material yield strength at temperature
$(\sigma_{aF})_K$	- amplitude of equivalent stresses	T	- loads from thermal expansions
$[\sigma]$	- nominal allowable stress (PNAE)	T1	- loads from temperature gradient in longitudinal direction
L_c	- Loads from Design Basis Accident	T2	- loads from temperature gradient along wall thickness
OBE	- Operating Basis Earthquake	W	- mechanical loads
P	- Internal Pressure	ZPGA _{SSE}	- Zero Period Ground Acceleration under SSE
R_m^T	- tensile strength at temperature	U	- Cumulative Usage Factor

REFERENCES

- 1 Protection against Internal Hazards Other than Fire and Explosions, IAEA Draft Safety Guide, Working ID DS 299, 2002
- 2 Norms for strength calculations of equipment and pipelines of nuclear power facilities. PNAE G-7-002-86.
- 3 U.S. Atomic Energy Commission, Regulatory Guide 1.46, Protection against pipe whip inside Containment, May 1973
- 4 Standard Review Plan, NUREG 0800, part 3.6.1, Plant Design for protection against postulated piping failures in fluid systems outside Containment, Rev. 2, October 1990
- 5 Standard Review Plan, NUREG 0800, part 3.6.2, Determination of rupture locations and dynamic effects associated with the postulated rupture of piping, Rev. 1, July 1981
- 6 Computer Software Code For Piping Dynamic Analysis dPIPE, Verification Manual Report No. co06-96x.vvk-0 I, St. Petersburg, 1997