

## **SEISMIC QUALIFICATION TESTS OF SELECTED TYPES OF RELAYS, USED IN KOZLODUY NPP**

**Pavel Spassov<sup>1</sup>, Marin Jordanov<sup>2</sup>, Boyko Nikolov<sup>3</sup>**

<sup>1</sup>Mechanical engineer, EQE Bulgaria AD, Sofia (pls@eqe.bg)

<sup>2</sup>Structural and seismic engineer, EQE Bulgaria AD, Sofia

<sup>3</sup>Electrical engineer, EQE Bulgaria AD, Sofia

### **ABSTRACT**

The main objective of the study was to qualify the existing equipment at Kozloduy NPP for seismic event, corresponding to the Revue Level Earthquake (RLE) for the site. This paper is devoted to the Seismic Qualification tests of selected ten types of relays.

The seismic qualification process comprised the following steps:

1. Review of the safety related relays and selection of the types to be qualified;
2. Development of specification for the Seismic Qualification procedures, including functional tests of the relays before, during and after the seismic excitation;
3. Performance of the specified Seismic Qualification;
4. Analyses of the results, conclusions and proposals.

Basic activities in step one included the minimization of the list of the relays to be qualified, considering their safety functions. Various type relays as a function have been selected and included in the test program.

The Required Response Spectra (RRS) were developed on the bases of the RLE for the site of the NPP. The Amplified Response Spectra (ARS) included the effects of amplification of the motion by the response of the structure, as well as the amplification due to the supporting conditions inside the cabinet or equipment. The functional performance of the relays during the seismic excitation was monitored for the following modes: non-operating, operating and transition.

The results of the tests have shown that some certain types of the tested relays are not properly designed from earthquake engineering point of view and should not be used in the safety systems.

### **INTRODUCTION**

The seismic qualification of the old design relays is part of project devoted to qualification of the important for the safety equipment in existing NPP. The electrical and control equipment was subject to test qualification, because of missing proper qualification data and relatively easy achievable qualification by test. In the frame of the project four groups of C&I and electrical equipment were selected for tests. They are relays, motor control centers, differential pressure transmitters and secondary devices for the same transmitters. The selection was done according equipment importance for the plant safety and its quantity in the safety systems. The qualification was performed taking into account international codes and standards for this type of equipment, especially IEEE standards and European documents.

The relays used in WWER-440 units at Kozloduy NPP perform safety functions as actuation of safety systems, and provision of signals and alarms for shift operators' support.

### **SELECTION AND DESCRIPTION OF THE TESTED RELAYS**

Since there are a great variety of relays used in WWER-440 units of the plant, the type relays to be tested were selected using the following criteria:

- Relays involved in the interlocks of the plant critical safety functions;
- The total quantity of the different models;
- All types of relays to be represented in the test;
- Test two samples per model. This decision was taken in order to have more than one sample to check the repetitiveness of results and to have a third spare one in case of failure of the sample, and in order not to reduce the number of different types to be tested (if three units per type had been considered, only 6 different ones could have been tested)

The range of the relays subjected to test included ten different models, which belong to four principle types – auxiliary relays, time relays, over-current relays and under-voltage relays. All of them are Russian design and production.

The relay models initially scheduled for testing were as follows (2 units per model):

- Auxiliary relays, type ПИ23УХЛ4
- Auxiliary relays, type ПИ-251
- Auxiliary relays, type ПИ8УХЛ4
- Auxiliary relays, type ПИУ-1-362
- Auxiliary relays, type ПИ25УХЛ4
- Time relays, type ТХ12ЗН
- Time relays, type БЛ-34УХЛ4
- Time relays, type ЭВ142У4
- Over-current relays, type РТ-40/0.2У4
- Under-voltage relays, type РН-54/320

## TEST FACILITY AND EQUIPMENT

Test facility is located in Steel Structures Research Laboratory of the University of Architecture, Civil Engineering and Geodesy, specialized in seismic research of structures in Sofia, Bulgaria.

The seismic excitation in horizontal direction is performed by means of a shaking table with a mounting surface of 1.5 by 1.5 m. This is a two component shaking table (horizontal translation in one direction and rotation about a vertical axis). It is used for a single axis testing in both horizontal axes (X and Y respectively). For vertical axis tests, one of the actuators is mounted in a vertical position. The attached to the piston rod platform has a size of 1.00/1.00m. The drive mechanisms for both shaking tables are servo-controlled, electro-hydraulic actuators, manufactured by Instron Ltd. They have the following capabilities given in Table 1.

Table 1. Shaking table basic characteristics

Frequency Range	0-100 Hz
Dynamic Load Capacity	± 50 kN
Maximum Stroke	± 50 mm
Maximum Velocity	270 mm/sec
Maximum Acceleration	10 g

The testing equipment used during this qualification program is listed in Table 2.

Table 2. Testing equipment

ITEM	MADE	MODEL	SERIAL No.	CALIBRATION/ACCURACY
Accelerometers	HBM-Germany	B-12/200	5108, 5110, 5113, 5115, 5116,	Calibrate in accordance with Instruction Manual
Amplifiers	HBM-Germany	KWS 3073	from 74279 to 74284	Calibrate with K3602 No. 1623, HBM, before measurement
Computer	RISK Electronics	AT486DX	887	Not Required
Computer	R.O.C.	EPS-425DX2	9200242	Not Required
Computer	INKO	AT286/10	1276	Not Required
ADC	MetraByte, USA	DAS16/F	SN 040636	Not Required
ADC	MetraByte, USA	DAS 8 PGA	SN 87518	Not Required
DAC	MetraByte, USA	DAC-02	SN 010839	Not Required
Digital multimeter	Mashtech	MY68	MG0113655	Accuracy 1.0
Analog voltmeter	-	EL20	6376274	Accuracy 0.2

## TEST METHOD

For the purposes of the seismic qualification corresponding test specification and test procedure were developed.

The seismic qualification tests were performed separately for the three components of the seismic excitation in X, Y and Z directions. Two levels of excitation are required: an Upper level corresponding to Safe Shutdown Earthquake(SSE) and a Lower level corresponding to Operating Basis Earthquake(OBE). A set of accelerograms corresponding to the Required Response Spectra are generated. The synthetic time histories have 40 sec duration with 20 sec strong motion part. The signals for the movement of the shaking table correspond to the generated accelerograms. The Test Response Spectra (TRS) are obtained for the recorded accelerograms of the shaking table movement. For comparison of the RRS and TRS their graphs are presented on the figures 1 and 2. All Response Spectra are for 5% damping.


The relays were mounted on a rigid platform in their normal service position. Supporting base frame is rigidly anchored to the shaking table by welding. Each one of the devices is fastened to the rigid platform by bolts.

The tested relays were mounted on the shaking table for horizontal excitation, first in X direction and second in Y direction. For excitation in Z direction they are mounted on the platform for vertical vibration.


## TESTING PROGRAM

The Seismic Qualification Program included the following activities:


- Preliminary visual inspection of the integrity of the specimens;
- Functional testing for electrical functionality verification before seismic tests;
- Mounting on the shaking table;
- Seismic qualification tests with monitoring of the selected signals for contacts' chatter;
- Visual inspection and functional tests after the completion of the seismic tests;
- Data processing and interpretation.




Lower Level



Lower Level



Upper Level



Upper Level

Fig.1. Response spectra TRS and RRS, OBE and SSE levels, X and Y direction of testing

Fig.2. Response spectra TRS and RRS, OBE and SSE levels, Z direction of testing

## TEST CONDITIONS

Two test levels corresponding to 5% damping factor were defined, considering the floor response spectra (FRS), which were increased to take into account the local amplification of the panels, due to various supporting conditions inside the cabinets or equipment. The FRS were based on the Review Level Earthquake (RLE), officially required for the seismic evaluation of the plant. Additionally, a Local Earthquake (LE) effect was considered. The tests in every direction were performed by three excitations at Lower level for seismic aging and followed by three excitations at higher level corresponding to Safe Shutdown Earthquake (SSE). During each series of excitation, the behavior of the tested equipment is monitored in three modes. The first mode corresponds to non-operating (de-energized state). The second mode required operating state (energized coils). The last one is the transient mode, during which change of state is introduced to the tested relays.

Particular requirements concerning test conditions for each type of relay are stated in the detailed Test Specification. For all of them the requirements according IEEE C37.98 standard were applied, taking into account specific way of their actuation and design.

Three type of relays have to be set before start of seismic test program – time relays (all types), over-current and under-voltage relays. The set values are shown in the following table. They were not changed during execution of seismic test program, with exception for under-voltage relays. The setting and adjustment values are presented in Table 3.

Table 3 Relay settings and adjustment

Relay type	Set value	Note
Time relays EB142Y4	10 seconds (time delay)	Delay was set in the middle of scale
Time relays BJI-34YXJI4	6, 12, 18 seconds (time delay)	There are 3 independent contacts, which have to be set to different values. The minimum possible values were used, in order to test relays' performance in transition mode during seismic excitations.
Overcurrent relays PT-40/0.2	200mA (current)	The setting is the maximum, in order to ensure proper test conditions – 25% and 200% of setting value
Undervoltage relays PH-54/320	200V (voltage)	The setting value is 0.9 of nominal voltage rate

Electric power supply is separated in four circuits. One loop for 220V supplies AC auxiliary and over-current relays. The second one is for 220V DC auxiliary and time relays. The third loop supplies 110V DC auxiliary relays. The last one ensures variable AC power supply for undervoltage relays using separate transformer.

For testing purposes 32 monitoring channels, split in two groups were used. During seismic tests only one group was monitored because of the limitation of the data acquisition system, so two identical excitations were performed in each stage in order to register performance of all relays.

## FUNCTIONAL TEST BEFORE SEISMIC EXCITATIONS

### *Mechanical check*

All relays were checked for mechanical damages, possible because of the improper storage, handling and transportation. No any damages were observed. After visual inspection they were mounted on the test facility. Their mechanical functionality was examined, applying nominal voltage/current to the coils. The change of state was checked using two methods: visually observing mechanical behavior and monitoring electrical signal from the contacts.

Two types time relays BJI-34YXJI4 and TX12 could not be checked visually.

All relays changed state properly.

After first functional test, time relays TX12 did not return back to their normal position. Because of this, it was impossible to perform seismic tests on this type relays.

### *Electrical check*

According test specification auxiliary relays powered by AC (PII-25YXJI4) have to be checked for pick up at 0.8 nominal voltage. Both of them picked up. Drop out voltage is also measured.

Time relays were checked for time delay.

Pick up and drop out voltage of under-voltage relays at 0.9Un (200V) setpoint were checked and recorded in the protocol.

All relays before seismic tests worked properly and their electrical parameters are inside allowable tolerances, with exception of TX12 relays. These type relays were excluded from testing program at this stage.

## **FUNCTIONAL TEST AFTER SEISMIC EXCITATIONS**

Following test specification, complete functional tests were performed in order to check the condition of tested equipment after completion of the seismic testing program.

### ***Mechanical check***

All relays were checked for mechanical damages. The relays kept their structural integrity. No problems with anchorage to test facility of the relay boxes were observed also. Their mechanical functionality was examined, applying nominal voltage/current to the coils. The change of state was checked exactly in the same way as in the test before seismic excitation.

All tested relays changed state properly.

### ***Electrical check***

According test specification, the auxiliary relays powered by AC (PII-25VXJ14) have to be checked for pick up at 0.8 nominal voltage. Both of them picked up. Pick up and drop out voltage is registered. Practically there were no variations from initially measured values.

Time relays were checked for time delay. Initially measured time delays were confirmed.

Pick up and drop out voltage of under-voltage relays at 0.9Un (200V) setpoint were checked and recorded in the protocol. Very small deviations were registered.

In addition electric insulation tests of relays were performed. Insulation was measured between contacts, coil-ground and metal components-ground. All relays pass the test – the insulation was more than 400M $\Omega$  at 1000V voltage applied.

No any mechanical damages and malfunctions induced from seismic excitations were registered. All relays after completion of seismic test program worked properly and their electrical parameters are identical with initially measured parameters.

### ***Conclusion about seismic aging of relays***

The tested relays were no destroyed by applied excitations. They keep their integrity and functionality unchanged, so they can perform reliable operation after seismic event.

## **FUNCTIONAL TESTS DURING SEISMIC EXCITATIONS**

Data acquisition system acquires monitoring channels using sampling rate of 1000samples/second for each channel. Voltage applied to monitored contacts is 5VDC and 8VDC.

### ***Deviations from test specification***

DC relays PII251 operated at 90-98% nominal voltage, test specification requirement is 100% nominal voltage (conservative).

All other DC relays operated at 93-96% nominal voltage, test specification requirement is 100% nominal voltage (conservative).

AC auxiliary relays PII-25 in operating mode were supplied with 100% nominal voltage, instead of 80% according test specification (non-conservative).

Over-current relays PT40/0.2 worked in operating mode at 235% of set current value - test specification requires 200%. In non-operating mode current was 27% of setting – requirement is for 25%. (conservative in operating mode)

Under-voltage relays PH-54/320 were energized exactly according test specification.

### ***Tests in X direction***

Non-operating mode: Closed contacts of relays PT-40 and PH-54 chattered in both excitation levels. Prompt contacts of time relays ЭB142 chattered also in both levels. Closed contacts of time relays BJI34 chattered at 30% (voltage varied between 70-100% continuously during excitations). All other relays pass the test.

Operating mode: Closed contacts of relays PT-40 and PH-54 chattered in both excitation levels. Signals from time relays BJI34 and prompt contacts of time relays ЭB142 were inadequate (possible bad contact of the circuits). All other relays pass the test.

Transition mode: Signals from time relays BJI34 and prompt contacts of time relays ЭB142 were inadequate (possible bad contact of the circuits). All other relays changed state properly. Nevertheless, the problems with closed contacts in both states (non-operating and operating) of under-voltage and over-current relays remained.

### ***Tests in Y direction***

Non-operating mode: Closed contacts of relays PT-40 and PH-54 chattered in both excitation levels. Prompt contacts of time relays ЭB142 chattered also in both levels. Closed contacts of time relays BJI34 chattered at 15-20% (voltage varied between 80-100% continuously during excitations). All other relays passed test.

Operating mode: Closed contacts of relays PT-40 and PH-54 chattered in both excitation levels. Extremely high chattering of PT-40 contacts was observed. One of auxiliary positioning relays PII-8 chattered 3 times at high excitation level. Signals from time relays BJI34 and prompt contacts of time relays ЭB142 were inadequate (possible bad contact on the circuits). All other relays passed test.

Transition mode: Signals from time relays BJI34 and prompt contacts of time relays ЭB142 were inadequate. Bad connection was found in relay BJI34 circuit after test at high excitation level, test was repeated and relays passed test successfully. Relays PII-8 was switched twice because of the operator fault, however they changed state properly following control signal. All other relays changed state properly. Nevertheless, the problems with closed contacts in both states (non-operating and operating) of under-voltage and over-current relays remained.

### ***Tests in Z direction***

Non-operating mode: Closed contacts of relays PT-40, PH-54 and prompt contact of time relays ЭB142 chattered in both excitation levels. At low excitation level they opened only once. One of the relays PII-23 chattered at high level. The same relay was inspected and adjusted after the test. The test was repeated and this relay passed test successfully. All other relays passed test.

Operating mode: Extremely high chattering of over-current relays PT-40 contacts was observed. One of under-voltage relays PH-54 chattered at high excitation level.

Transition mode: All relays changed state properly. Nevertheless, the problems with closed contacts in both states (non-operating and operating) of under-voltage and over-current relays remained.

### ***Summary about Functional Performance during Seismic Event***

Due to time limitations as an important factor and data acquisition system capacity on the other hand, the complex wiring diagram of the monitored contacts was applied. A great number of contacts connected in series, or in parallel were monitored by 32 sampling channels of the acquisition system. The relays demonstrating loss of control signal or chatter were subjected to thorough check of wiring

connection and were rewired for individual control of monitored contacts. The final results are as reported below.

Over-current relays PT-40 and under-voltage relays PH-54 chatter in all three investigated directions in both states – operating and non-operating. They do not have reliable performance even in low excitation levels. This behavior was not surprising taking into account their specific design and way of actuation.

Snap action contact of one relay  $\text{ЭB142}$  failed in one horizontal and in vertical direction of testing in non-operating mode. Time delay contacts of the same type relays did not experience any failure.

One normally closed contact of time relays BJI34 chattered in all tested directions. Three other normally closed contacts of the same relays chattered also in X direction of the testing. So, 4 of total 12 monitored contacts of this type of relays failed in X direction.

The time relays TX12 performed reliably in all tests.

All time relays operated exactly without variation of preset time delays.

Auxiliary relays PII8, PII23, PII25, PII251 and PIIY1 performed reliably without any failure.

## CONCLUSIONS

All auxiliary relays involved in the seismic qualification test demonstrated reliable operation, keeping the required state of all contacts, as well as prompt change of contacts position in transition mode.

Two out of three types of time relays experienced some problems with instant or delayed contacts.

Over-current as well as under-voltage relays did not keep their contacts closed not only during high excitation levels, but at low level as well.

No closure of opened relay contacts is registered. So, all monitored problems are allocated to closed contacts. Therefore no one relays armature had changed position during seismic tests.

In transition mode all relays changed their state properly.

After seismic tests all tested relays keep reliable operability, without changing settings and electrical parameters.

The tested auxiliary relays have robust design, and due to it no single contact chatter or other component failures were registered. The time relays with exception of one type TX12ZN experienced some problems, mostly with instant contacts and some normally closed contacts, as well. So, in any specific case, it is recommended to perform seismic test or to use supplier prequalified equipment with corresponding certificates.

Mechanical over-current and under-voltage relays which has old design, like tested PT-40 and PH-54, could not be seismically qualified, because of their inherit vibration vulnerability. Their adjustment of setpoint, relies on very light and precise balance between electromagnetic force from one hand and fine spring on the other. Such design could not involve seismic stability of relays' contact system. It is recommended that the relays of these types to be replaced in nuclear power plants, situated at seismic regions.

## REFERENCES

1. US Nuclear Regulatory Commission, Regulatory Guide 1.100, Seismic Qualification of Electric and Mechanical Equipment for Nuclear Power Plants, 1988;
2. IEEE Std C37.98-1987 IEEE Seismic Testing of Relays;
3. IEEE Std 344-1987 Recommended Practice for Seismic Qualification of Class 1E Equipment for Nuclear Power Generating Stations;
4. International Standard CEI/IEC 980-1989 Recommended Practice for Seismic Qualification of Electrical Equipment for Nuclear Generating Stations;



5. International Standard CEI/IEC 68-3-3/1991 Environmental Testing. Part 3: Guidance. Seismic Test Methods for Equipment;
6. Development of Required Response Spectra for the Seismic Qualification of Electrical and Instrumentation Components for Kozloduy NPP, Units 1-4, Empresarios Agrupados International S.A.
7. Test Specification for Relays Seismic Qualification, Report 4401-R-01, Issue 1, EQE Bulgaria, June 1999;
8. Report for Seismic Test of Selected Types of Relays for Units 1-4, Kozloduy NPP, University of Architecture, Civil Engineering and Geodesy, Sofia, August 1999